

Division of  
**UNITED  
TECHNOLOGIES**™

AVAILABLE TO THE PUBLIC

Unclas  
G3/54 14381



**HAMILTON STANDARD**



CR 137769  
SVHSER 6821

FUSIBLE HEAT SINK FOR EVA THERMAL CONTROL

FINAL REPORT

BY

GEORGE J. ROEBELEN, JR.

PREPARED UNDER CONTRACT NO. NAS 2-8912

BY

HAMILTON STANDARD

DIVISION OF UNITED TECHNOLOGIES CORPORATION  
WINDSOR LOCKS, CONNECTICUT 06096

FOR

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION  
AMES RESEARCH CENTER  
MOFFETT FIELD, CALIFORNIA 94035

DECEMBER 1975

TABLE OF CONTENTS

<u>Section Title</u>	<u>Page</u>
Foreword	1
Introduction	2
Summary	3
Conclusions	4
Recommendations	5
Nomenclature	7
Fusible Material Investigation	9
Slurry Evaluation	9
System Simulation Testing	11
Conclusions	20
Preliminary Design	22
Specification, Fusible Heat Sink System	22
Recommended System	23
System Selection Justification	26
Component Selection	28
Weight Summary	38
Sample Weight Calculations - Pump/Motor	40
Performance Analysis	41
Recharge Mode Operation	41
Normal Mode Operation	43
Summary	43
Component and System Specifications	54
System Specification	54
Component Specifications	54
Appendix A	A-i
Appendix B	B-i

LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1	Calorimeter Test Curve	12
2	Cooling Curve	13
3	Fusible Heat Sink Schematic	15
4	System Simulator Module	17
5	Module and Instrumentation	18
6	Freezer Installation	19
7	Fusible Heat Sink System Concept	24
8	System Temperature/Flow Characteristics	35
9	Plate Fin Heat Exchanger Core	37
10	Thermal Response of Fusible Heat Sink During Cooldown	44
11	Fusible Heat Sink - Cooldown Condition	45
12	Fusible Heat Sink Cooldown Side View - Time = 10 Hours	46
13	Fusible Heat Sink Cooldown Expansion Circulation Tube - Time = 10 Hours	47
14	Fusible Heat Sink Cooldown Top View - Time = 10 Hours	48
15	Fusible Heat Sink Cooldown Side View - Time = 30 Hours	49
16	Fusible Heat Sink Cooldown Expansion Circulation Tube - Time = 30 Hours	50
17	Fusible Heat Sink Cooldown Top View - Time = 30 Hours	51
18	Fusible Heat Sink Warmup Condition Pump Outlet Temperature Versus Time	52
19	Liquid Cooling Garment Heat Exchanger Concept	55



LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
I	Power Densities	30
II	Calculated Weight Summary	39

FOREWORD

This report has been prepared by the Hamilton Standard Division of United Technologies Corporation for the National Aeronautics and Space Administration, Ames Research Center in accordance with the requirements of Contract NAS 2-8912, Fusible Heat Sink for EVA Thermal Control.

Appreciation is expressed to the NASA Technical Manager, Mr. Bruce Webbon of the Ames Research Center, for his guidance and advice.

Hamilton Standard personnel responsible for the conduct of this program were Mr. Daniel J. Lizdas, Project Manager and Mr. George J. Roebelen, Jr., Program Engineer. Appreciation is expressed to Mr. John S. Lovell, Chief, Advanced Engineering, Mr. Earl K. Moore, Technical Specialist, Mr. W. Clark Dean, II, Design Engineer, Mr. Edward H. Tepper, Analytical Engineer, and Mr. Gerald Winter, Analytical Engineer, whose efforts made the successful completion of this program possible.

Hardware concept drawings have been prepared as a result of effort expended during the period covered by this report. These drawings, Fusible Heat Sink System - Packaging Concept, SVSK 91745 Sheet 1 and 2, and Fusible Heat Sink System - Heat Exchanger Concept, SVSK 91780, have been transmitted under separate cover.

## INTRODUCTION

Future manned space exploration missions are expected to include requirements for astronaut life support equipment capable of repeated use and regeneration for many extravehicular activity (EVA) sorties. In anticipation of these requirements, NASA/ARC funded two contracts (NAS 2-6021 and NAS 2-6022) for the study of Advanced Extravehicular Protective Systems (AEPS). The purpose of these studies was to determine the most practical and promising concepts for manned space flight operations projected for the late 1970's and 1980's and to identify areas where concentrated research would be most effective in the development of these concepts.

One regenerative concept for astronaut cooling utilizes a fusible slurry pack as the primary heat sink for a liquid cooling garment (LCG) cooling system. A solution of potassium bifluoride in water, developed under NASA/ARC Contract NAS 2-7011, is employed as the major constituent in the slurry.

This report describes the effort funded by NASA/ARC under Contract NAS 2-8912 during which a heat sink system utilizing a phase change slurry material was preliminary designed and analyzed, and candidate phase change slurry materials were evaluated.

SUMMARY

The objective of the Fusible Heat Sink for EVA Thermal Control program is to evaluate candidate phase change slurry materials and to preliminarily design and analyze a heat sink system utilizing a phase change slurry material to be used eventually for astronaut cooling during manned space missions.

A fusible material investigation was conducted to develop a suitable slurry mixture for the fusible heat sink application and to test the critical properties of the fusible material in a simulated system. This investigation has demonstrated that a slurry with the composition of 45 ml of 30 g potassium bifluoride per 100 g water solution combined with 5 ml of ethanol provides the desired thermal storage capacity and slurring properties required for satisfactory fusible heat sink operation.

Utilizing the selected slurry material, a preliminary design was conceived for the fusible heat sink system, and an extensive math model was written to describe the thermal operation of the system during normal (astronaut cooling) and recharge (refreeze) conditions. The output from the math model verifies the desired thermal gradients necessary for fusible heat sink operation. Hardware drawings have been prepared describing the fusible heat sink concept. These drawings, Fusible Heat Sink System - Packaging Concept, SVSK 91745 Sheet 1 and 2, and Fusible Heat Sink System - Heat Exchanger Concept, SVSK 91780, have been transmitted under separate cover.

Based on the results of this program, the Fusible Heat Sink for EVA Thermal Control has been demonstrated to be an acceptable concept for EVA Thermal Control.

CONCLUSIONS

It is concluded that a slurry of potassium bifluoride/water/ethanol meets all requirements for a regenerable heat sink material and that a system can be designed to perform satisfactorily using this material.

### RECOMMENDATIONS

The studies and test results of this program have indicated that a slurry system can be designed to satisfy the Fusible Heat Sink for EVA Thermal Control requirements. Therefore, it is recommended that a laboratory demonstration module aimed at demonstrating the feasibility of the concept generated by this program be designed, analyzed, manufactured, and tested.

NOMENCLATURE

Btu	British thermal unit
Btu/hr	British thermal unit per hour
Btu/hr-ft-°F	British thermal unit per hour-foot-degree Fahrenheit
Btu/hr-ft <sup>2</sup> -°F	British thermal unit per hour-square foot-degree Fahrenheit
Btu/lb-°F	British thermal unit per pound-degree Fahrenheit
cal	calorie
cal/g	calorie per gram
cm	centimeter
°C	degree Celsius
DC	direct current
EVA	extravehicular activity
ft	foot
°F	degree Fahrenheit
g	gram
g/s	gram per second
HX, H/X	heat exchanger
H <sub>2</sub> O	water
in	inch
J	joule
J/g	joule per gram
J/g-°C	joule per gram-degree Celsius
J/s	joule per second
J/s-m-°C	joule per second-meter-degree Celsius
kg	kilogram
kg/hr	kilogram per hour
KHF <sub>2</sub>	potassium bifluoride
kJ	kilojoule
kJ/hr	kilojoule per hour
kPa	kilopascal (kilonewton per square meter)



NOMENCLATURE  
(Continued)

lb	pound
lb/hr	pound per hour
lb/min	pound per minute
LCG	liquid cooling garment
LSS	life support system
m	meter
mcp	thermal mass
min	minute
ml	milliliter
NPT	national pipe thread
O.D.	outside diameter
Pa	pascal (newton per square meter)
PLSS	portable life support system
psi	pound per square inch
psia	pound per square inch absolute
T.C.	thermocouple
T <sub>1</sub> , T <sub>2</sub> , T <sub>3</sub> , T <sub>4</sub>	temperature
VDC	direct current volt
W	watt
W/cm-°C	watt per centimeter-degree Celsius
W/cm <sup>2</sup> -°C	watt per square centimeter-degree Celsius
W <sub>1</sub> , W <sub>3</sub> , W <sub>5</sub>	flow rate
ΣG	sum of conductances to adjacent parts

The Fusible Heat Sink for EVA Thermal Control program was performed in four phases. These phases are discussed in the following sections:

Fusible Materials Investigation

Preliminary Design

Performance Analysis

Component and System Specifications

### FUSIBLE MATERIAL INVESTIGATION

Based on the results of the Thermal Storage Materials effort conducted under NASA/ARC Contract NAS 2-7011, the phase change material was selected at the inception of this Fusible Heat Sink program. A slurry containing a thermal storage solution of 30 grams potassium bifluoride ( $\text{KHF}_2$ ) per 100 grams of water mixed with a suitable slurrying admixture will be developed. Following is a description of the effort associated with this task.

#### SLURRY EVALUATION

In order to evaluate the suitability of a particular slurry for our specific application, the following list of required characteristics has been established:

Relatively high thermal absorption capability

Absorption capability in temperature range of  $-15^\circ\text{C}$  to  $0^\circ\text{C}$

Pumpable when "frozen"

Low toxicity of vapor at room temperature and pressure

Three categories of mixtures were selected for initial investigation; all satisfy the vapor toxicity requirement. The relatively low level of ethanol could be mildly exhilarating but not toxic.

30g  $\text{KHF}_2$  per 100g  $\text{H}_2\text{O}$

30g  $\text{KHF}_2$  per 100g  $\text{H}_2\text{O}$ , ethylene glycol admixture

30g  $\text{KHF}_2$  per 100g  $\text{H}_2\text{O}$ , ethanol admixture

Six 50 ml specimens were prepared and capped in Lexan centrifuge tubes of 0.10 cm wall thickness and 2.65 cm internal diameter:

Sample #1	50 ml of 30g $\text{KHF}_2$ /100g $\text{H}_2\text{O}$
Sample #2	47.5 ml of 30g $\text{KHF}_2$ /100g $\text{H}_2\text{O}$ 2.5 ml of ethylene glycol
Sample #3	45 ml of 30g $\text{KHF}_2$ /100g $\text{H}_2\text{O}$ 5 ml of ethylene glycol
Sample #4	47.5 ml of 30g $\text{KHF}_2$ /100g $\text{H}_2\text{O}$ 2.5 ml of ethanol

Sample #5      45 ml of 30g  $\text{KHF}_2$ /100g  $\text{H}_2\text{O}$   
                  5 ml of ethanol

Sample #6      40 ml of 30g  $\text{KHF}_2$ /100g  $\text{H}_2\text{O}$   
                  10 ml of ethanol

Each of the six specimens was cooled a minimum of 3 times each to final temperatures of  $-17.8^\circ\text{C}$  ( $0^\circ\text{F}$ ),  $-15^\circ\text{C}$  ( $5^\circ\text{F}$ ), and  $-12.2^\circ\text{C}$  ( $10^\circ\text{F}$ ).

Samples 1, 2, and 3 were solid at each of the three final temperatures of  $-17.8^\circ\text{C}$  ( $0^\circ\text{F}$ ),  $-15^\circ\text{C}$  ( $5^\circ\text{F}$ ), and  $-12.2^\circ\text{C}$  ( $10^\circ\text{F}$ ) and were judged unacceptable as slurry materials.

Samples 4, 5, and 6 all exhibited a slurring effect where the outer portions of the mixture, the part that "froze" first, were relatively solid, and the inner core remained liquid/slushy. The only immediately noticeable difference between the three samples was that the size of the core was directly related to the ethanol content. The fact that the inner portion of the specimen remained liquid leads us to conclude that the proper approach is to package the system such that the fluid contained in the pump and associated lines is the last to chill and, hence, remains liquid. Proper location of components and insulation panels can accomplish this desired slush distribution. The liquid portion flows around the periphery of the frozen portion, gradually thawing the entire slurry.

During several cooling runs, Sample #6 failed to solidify at a temperature of  $-17.8^\circ\text{C}$  ( $0^\circ\text{F}$ ). Rapid agitation of the sample produced a crystallization that was thought to be freezing of the fluid. However, further investigation indicated that the freezing point of the 20% ethanol slurry is in the  $-17.8^\circ\text{C}$  ( $0^\circ\text{F}$ ) range, thereby accounting for the occasional failure to solidify. The solubility of  $\text{KHF}_2$  in  $\text{H}_2\text{O}$  in this temperature range is approximately 8g per 100g  $\text{H}_2\text{O}$ . Apparently, the precipitate that occurred during agitation of the unfrozen sample was  $\text{KHF}_2$  rather than ice crystals. A description of process by which the freezing point and concentration properties were obtained is contained in the System Simulation Testing section following.

An assessment of the properties of the six samples tested indicates that Sample #4 (5% ethanol) and Sample #5 (10% ethanol) exhibit the characteristics required for satisfactory performance in our application. The significant differences between Sample #4 and Sample #5 are: Sample #4 (5% ethanol) would be expected to have a slightly greater heat absorptive capability per unit volume due to its lesser volume of ethanol, and Sample #5 (10% ethanol) has been observed to have a larger liquid center in the

frozen condition. Inasmuch as the Fusible Heat Sink concept depends on the slurry having a liquid center for start up conditions, it was decided to follow the conservative approach and select the 10% ethanol slurry for further investigation. Once the feasibility of this concept has been proven, additional effort could be expended to study the possibility of reducing the slurry ethanol content.

It was decided to utilize the United Technologies Research Center, the agency that performed the Thermal Storage Materials effort under Contract NAS 2-7011, to perform calorimeter testing of the 10% ethanol specimen to ensure that the addition of ethanol to the  $\text{KHF}_2/\text{H}_2\text{O}$  solution did not alter the manner in which the  $\text{KHF}_2$  precipitated during freezing and, hence, degrade the heat absorptive capability of the potential slurry material. Figure 1 illustrates the results of this calorimeter testing. As shown, the 10% ethanol specimen produced a heat absorption of 487 J/g (116.4 cal/g) as compared to a predicted value of 456.3 J/g (109.1 cal/g) (90% of the 507 J/g (121.2 cal/g) obtained during previous testing of the 30g  $\text{KHF}_2/100\text{g H}_2\text{O}$  solution). The specific gravity of the 10% ethanol specimen was measured as 1.10 at 21.1°C (70°F). Therefore, the heat absorption per unit volume of the 10% ethanol specimen is approximately 535.7 J/cm<sup>3</sup> (8.32 Btu/in<sup>3</sup>). These values of heat absorption are as expected and are acceptable for Fusible Heat Sink slurry.

A cooling curve was run on the 10% ethanol specimen to determine the temperature range over which the bulk of the heat was absorbed. This curve is obtained by freezing the specimen and allowing it to thaw at room temperature. Specimen temperature vs. time is plotted in Figure 2 which shows that the majority of heat absorption has been completed by the time the specimen reached -5°C (23°F).

An experiment was conducted to determine the volume increase of the 10% ethanol slurry during freezing. A quantity of 20 ml of liquid slurry was placed in a graduated cylinder and frozen. The frozen slurry volume was measured at 20.9 ml ± 0.1 ml. This translates into a volume increase during freezing of 4 to 5%.

The 10% ethanol specimen satisfies all of the established slurry requirements; system simulation testing was conducted using this solution.

#### SYSTEM SIMULATION TESTING

The object of conducting system simulation testing is to verify satisfactory performance of the selected slurry when subjected to conditions encountered during actual system operation.




FIGURE 1: CALORIMETER TEST CURVE





FIGURE 2: COOLING CURVE




The system concept, described in the following paragraphs, contains a suitable amount of slurry that is "frozen" in preparation for usage. During usage, the liquid portion of the slurry is pumped from the slurry storage tank through the LCG heat exchanger where heat is absorbed from the LCG cooling loop, and back to the slurry tank. When the entire slurry is "thawed" by contact between the liquid portion of the slurry and the frozen slurry interface, the system is removed from the LCG heat exchanger interface and returned to the freezer for recharge (refreezing, etc.). The problem to be solved revolves around demonstrating that the system can, in fact, be configured in a manner that locates the liquid portion of the "frozen" slurry in the required location. Specifically, there must be liquid slurry in the pump, interconnecting lines, and LCG heat exchanger quick disconnects at all times to allow slurry circulation when the slurry has been "frozen".

The configuration selected by Hamilton Standard, shown in Figure 3, incorporates a main slurry tank and an expansion chamber interconnected by a check valve. During normal operation, the slurry flows from the main slurry tank, through the pump inlet screen, through the pump, out the outlet quick disconnect, through the LCG heat exchanger, in the inlet quick disconnect, through the expansion chamber, and through the check valve back to the main slurry tank. In this manner, the slurry stream removes heat from the LCG heat exchanger and absorbs it within the slurry, thereby melting the slurry and redissolving the  $\text{KHF}_2$  in the  $\text{H}_2\text{O}$  solvent. ( $\text{KHF}_2$  has a negative heat of solution with  $\text{H}_2\text{O}$ , thereby, heat is absorbed during mixing.)

Recharge is accomplished by disconnecting the LCG heat exchanger from the system at the quick disconnects and connecting the expansion circulation tube to these quick disconnects as shown in Figure 3. The system with the expansion circulation tube attached is placed in a  $-15^\circ\text{C}$  ( $5^\circ\text{F}$ ) freezer for chilling. The system insulation during recharge is arranged to allow easy heat transfer through the main slurry tank and to resist heat flow through the expansion circulation tube, the quick disconnects, and the expansion chamber. With this configuration, the slurry in the main slurry tank will cool more rapidly than the fluid in the insulated area and, hence, will start to freeze first. As the slurry in the main slurry tank freezes at external surfaces, it expands, forcing liquid slurry from the unfrozen center through the insulated expansion circulation tube and into the expansion chamber. The check valve prevents flow directly from the main slurry tank to the expansion chamber. As the slurry starts to freeze, the  $\text{H}_2\text{O}$  becomes ice and the  $\text{KHF}_2$  precipitates. The ethanol separates from the freezing mass and remains liquid, thereby increasing the ethanol content of the unfrozen portion until the concentration point where the slurry will not freeze is reached.



NORMAL OPERATION




RECHARGE

FIGURE 3: FUSIBLE HEAT SINK SCHEMATIC

All this time, the liquid slurry with increasing ethanol content is being forced through the expansion circulation tube by the expansion of the freezing slurry in the main slurry tank. A small externally powered electric heater supplies heat to the expansion circulation tube to prevent it from freezing before the ethanol content has reached sufficient concentration to inhibit freezing. At the point where the entire system is chilled to  $-15^{\circ}\text{C}$  ( $5^{\circ}\text{F}$ ), the liquid slurry is strategically located in the pump, quick disconnects, expansion circulation tube, and other central areas where it allows a flow path when the pump is energized. The system is made ready for use by buttoning up the insulation around the main slurry tank, removing the expansion circulation tube and electrical connector, and connecting the unit to the LCG heat exchanger.

A system simulator module was constructed, as shown in Figure 4, with thermocouples located as shown. Figure 5 shows the module with the LCG heat exchanger simulator attached to the multipoint recorder, and Figure 6 shows the module in the  $-15^{\circ}\text{C}$  ( $5^{\circ}\text{F}$ ) freezer.


Thermal insulation was applied to the expansion chamber, the motor and magnetic drive, and the expansion circulation tube. A section of heater tape was wrapped along the expansion circulation tube because the resistance paths of the simulator were not representative of the thermal paths that will be encountered in the actual system design. Specifically, the plexiglass wall used in the main slurry tank for visibility presents a significantly greater thermal resistance than a metal wall. Conversely, the relatively bulky configuration of the expansion circulation tube and quick disconnects on the module present a significantly lower thermal resistance compared to the anticipated well insulated expansion circulation tube design. The intent was to use the 10 watt heater intermittently to keep the expansion circulation tube temperature from falling faster than the main slurry tank temperature and prevent the tube from freezing prematurely. It is estimated that less than 1 W will be required for the actual Fusible Heat Sink configuration. No heat was applied after the system reached  $-5^{\circ}\text{C}$  ( $23^{\circ}\text{F}$ ) which is slightly above the freezing point of the slurry per Figure 2. The actual system is designed, and the math model thermally verifies that the 1 W is sufficient to insure that the expansion compensation tube temperatures does not cool more rapidly than the main slurry tank.



SS-12034-4


FIGURE 4: SYSTEM SIMULATOR MODULE





SS-12032-4

FIGURE 5: MODULE AND INSTRUMENTATION



SS-12033-4

FIGURE 6: FREEZER INSTALLATION



The system simulator module with the expansion circulation tube installed was inserted in the freezer as shown in Figure 6. A circulating fan in the freezer was used to insure uniform temperature throughout the freezer. The multipoint recorder was started, and the temperatures of the fourteen thermocouples located per Figure 4 were recorded. As expected, the temperatures at the expansion circulation tubes (T.C. 9, 10, 13, 14) fell more rapidly than the temperatures in the main slurry tank. The 10 watt heater tape surrounding the expansion circulation tube was energized for 10 minutes per hour for a period of six hours at which time the entire simulator had reached the  $-5^{\circ}\text{C}$  ( $23^{\circ}\text{F}$ ) point where the freezing process starts. From this point on, no heat was applied to the expansion circulation tube. An additional sixteen hours of freezing was applied at which time the simulator had stabilized at approximately  $-15^{\circ}\text{C}$  ( $5^{\circ}\text{F}$ ). The multipoint recorder was turned off and the simulator removed from the freezer for examination. After removal of the insulation, visual examination of the simulator (frost had to be wiped off every minute or so) showed that the liquid portion of the slurry had indeed been pushed from the main slurry tank through the expansion circulation tube, and into the expansion chamber. The expansion compensation accumulator showed significant compression. As best as could be determined visually, liquid slurry was located in the pump area, expansion circulation tube area, and check valve area. Additional proof of the satisfactory operation of the expansion circulation tube was evident in that the main slurry tank was intact; any trapped volume of slurry would have fractured the container. Cold start of the pump/motor was attempted unsuccessfully. This was taken as a motor seize-up because mere stalling of the pump causes the magnetic drive to slip. The motor had been soaked with slurry during simulator loading operation. The pump/motor was disassembled and inspected. Excessive torque was required to rotate the pump shaft. Pump disassembly showed a sludge had become imbedded in the shaft bearings. The cold start problem will be examined further during the follow-on program.

An analysis of the portion of the 10% ethanol slurry remaining liquid after being cooled to  $-15^{\circ}\text{C}$  ( $5^{\circ}\text{F}$ ) shows the breakdown to be 21.5% vol. ethanol and 78.5% vol.  $\text{KHF}_2/\text{H}_2\text{O}$  with a  $\text{KHF}_2$  concentration of approximately 8g per 100g  $\text{H}_2\text{O}$ . This compares to an original composition of 10% vol. ethanol and 90 vol.  $\text{KHF}_2/\text{H}_2\text{O}$  with a  $\text{KHF}_2$  concentration of 30g per 100g  $\text{H}_2\text{O}$ . Thus, the original assumption that the  $\text{KHF}_2/\text{H}_2\text{O}$  solution fractionally freezes out of the total solution, leaving a concentrated ethanol liquid was verified.



### CONCLUSIONS

Based on the results of the slurry evaluation and subsystem simulation testing, it is possible to conclude that the 10% ethanol slurry behaves satisfactorily as anticipated, and the system configuration, using supplementary heat, positions the liquid portion of the slurry in the required positions in the system loop.

This last conclusion is further verified by the Math Model described in the Performance Analysis Section in which the thermal characteristics of normal operation and recharge for the final configuration are analyzed and established.

PRELIMINARY DESIGN

A concept for a preliminary design of a heat sink system utilizing a potassium bifluoride/water/ethanol phase change material has been generated. The following pages describe the selected system and present justification for the system and component selection.

SPECIFICATION, FUSIBLE HEAT SINK SYSTEM

Non-venting, non-umbilical.

Separable from the primary LSS with the only scar being the quick-disconnects. The liquid/liquid heat exchanger remains with the primary LSS.

Self-contained with its own power source, pump, and accumulator.

2,110 kJ (2,000 Btu) capacity.

10°C (50°F) LCG cooling loop temperature capability.

Fusible mode only, i.e., no evaporation at any time.

Control of heat rejection will be accomplished by varying flow parameters in the LCG loop with the fusible system loop operating with steady flow.

Heat sink to be replaceable in vacuum by one man if additional capacity is required to extend duration.

Heat Rejection Rates

Minimum - 117 J/s (400 Btu/hr)  
Average - 440 J/s (1,500 Btu/hr)  
Maximum - 586 J/s (2,000 Btu/hr)

Duty Cycle

One regeneration/usage per 24 hours  
System capability goal 100 regenerations

Vehicle Interfaces

Freezing/storage provisions - as required by system  
Power penalties - not available

## RECOMMENDED SYSTEM


Figure 3 shows the schematic relationship of the components in the recommended Fusible Heat Sink System. Normal operation and recharge of this system was briefly described in the previous section. Components of the system are immersed in the slurry tank to maximize packing density and, hence, minimize the total package volume. A partition separates the main slurry tank containing the pump/motor from the remainder of the tank containing the battery and the expansion compensation accumulator. Volume changes of the liquid caused by melting ice is compensated for by the air filled rubber bladder accumulator in this section. A check valve is located in the partition to allow flow from the accumulator section into the main section while preventing reverse flow during recharge. Flow from the check valve is directed through a tube that distributes the return flow uniformly through the slurry tank, thus preventing channeling. The pump outlet is delivered through a zero spill, self-sealing, quick disconnect to the LCG heat exchanger located in the LCG transport loop. After cooling the LCG transport loop, the fluid returns to the accumulator section of the slurry tank through a second disconnect. The fluid then flows through the check valve and distribution tube into the pump section of the slurry tank and through a screen into the pump inlet. The screen prevents large chunks of ice that could stall the pump from entering the pump inlet. Figure 7 shows the packaging arrangement of the system.

After all the ice has melted, the unit must be recharged for re-use. A portion of the insulation blanket that covers the unit during use is removed from the slurry tank walls to speed the freeze up process. The insulation that remains covers the top of the tank, the side of the tank in the accumulator area, and a portion of the side of the tank where the pump is closest to the wall. This selective insulation technique guarantees the proper rate of heat transfer with the result that the center of the slurry tank in the area of the pump inlet is the last to freeze, assuring a high ethanol content there at the completion of the freeze up cycle. A special electrically heated section of insulated pipe containing mating halves of the disconnects is connected to the unit to act as an expansion circulation tube. Refer to Figure 3. It is necessary to heat this tube during the freeze up cycle due to the low thermal mass of the fluid contained in the tube. External power of less than 1 watt will be used by the heater. The unit is then placed in a freezer and cooled to  $-15^{\circ}\text{C}$  ( $5^{\circ}\text{F}$ ). As the fluid cools, ice crystals will form in the main slurry tank increasing the volume of the mixture. Since the check valve prevents reverse flow from the main section of the

**HAMILTON STANDARD**



**REPRODUCIBILITY OF THE  
ORIGINAL PAGE IS POOR**



**FOLDOUT FRAME**




FIGURE 7: FUSIBLE HEAT SINK  
SYSTEM CONCEPT

slurry tank through the partition to the accumulator section, liquid is forced through the screen, pump, disconnects, and the expansion circulation tube to reach the accumulator section where the volume increase can be accommodated. This process has the effect of assuring that ethanol which is concentrated in the center of the tank as the slurry freezes is present in the pump and disconnects at the completion of the freeze up cycle, thus assuring their proper operation when the expansion circulation tube is removed and the unit is put in service. Concentration of ethanol also occurs in the check valve due to the progressive freeze up of the fluid in the distribution tube with the check valve located in the last to freeze area.

The battery is charged concurrently with the freeze up operation using pins of the same connector that delivers battery power to the pump/motor during unit operation. This connector, as well as an on-off switch and battery pressure relief valve, are located in a recess at the top of the unit and are accessible through a flap in the insulation cover.

Once the unit is frozen and is ready to be used, mechanical attachment to the suit is achieved by utilizing the two quick disconnects as two points of a 3-point mounting system; the third point being a ball lock pin. Removal of the ball lock pin allows actuation of a disconnect release lever. The pin and the lever are both located in the recess on the top of the unit. When the lever is pulled, two separate rods attached to the lever operate cams at each disconnect that depress the ball retaining sleeve of the disconnect allowing separation of the mated halves of the disconnect. During installation, the lever need not be actuated since a push on the unit will connect the disconnects. Inserting the ball lock pin completes the installation and prevents accidental release of the disconnects.

The recommended system excluding the LCG heat exchanger is 30.5 cm (12 in) high, 26.7 cm (10.5 in) wide, and 14.0 cm (5.5 in) deep (see Figure 7) and weighs 10.52 kg (23.19 lb) wet. During the battery charging period of 10 hours, 2.8 watts of power will be required for the battery. One watt will be required for the tube heater during the 24 hour freeze up period.

The recommended LCG heat exchanger is 3.6 cm (1.4 in) deep, 17.8 cm (7.0 in) long, and 16.0 cm (6.3 in) wide with a 17.8 cm (7.0 in) x 12.2 cm (4.8 in) x 0.76 cm (0.3 in) basic core. The heat exchanger weighs 1.56 kg (3.45 lb) wet.

A detailed weight summary is included at the end of this section.

## SYSTEM SELECTION JUSTIFICATION

The components required for the basic system are:

- Pump - to circulate the fluid
- Motor - to drive the pump
- Source of Electrical Power - to drive the motor
- Tank - to hold the slurry
- Volume Compensation Drive - to allow expansion and contraction of the fluid
- Heat Exchanger - to cool the LCG heat transport loop water
- Disconnects - to allow separation of all but the heat exchanger from the LCG for recharging of the unit

Many factors were considered during the system selection process resulting in refinements to the basic system to assure that the final configuration successfully met all the system operation requirements in the smallest, lightest, most adaptable package. A brief discussion of these system considerations follows.

System Design Considerations

The primary consideration in the design of the system was to prevent freezing of the components in the system during the freeze up period thereby assuring proper operation during subsequent use. The two components of primary concern, regardless of configuration, are the pump and the quick disconnects. These components have moving parts that could jam and fail to operate properly if they were allowed to ingest large ice chunks, or if fluid in them froze solid during freeze up. Locating the pump inlet at the center of the slush tank assures a concentration of alcohol present at the inlet when the unit is turned on, but chunks of slush might still be ingested. For this reason, a screen is included at the pump inlet to filter out any ice particles that could lodge in the pump or any small passage downstream. The screen also tends to distribute the flow of fluid to the pump inlet over a large area, thereby preventing channeling that would reduce the efficiency of the unit.

The disconnects are, by necessity, located at the face of the unit and could not be located in the "last to freeze" area to assure ice would not jam their internal parts. An electrical heating element was considered as a thaw out device but would have the undesirable effect of imposing additional battery weight on the system.

An alternate scheme was devised and finally incorporated in the recommended configuration that utilizes a baffle in the slush tank between the main slurry tank containing the pump inlet and the accumulator. During normal operation, return fluid enters the accumulator side of the baffle and then flows through a check valve in the baffle to the main slurry tank. During freeze up,



the check valve prevents liquid flow from entering the accumulator section to relieve volume expansion from ice formation. Instead, the fluid is forced to flow through the pump and through the disconnects which are interconnected by a thermally insulated and heated "expansion circulation tube" into the accumulator section of the slurry tank. This technique results in liquid of high ethanol concentration being present in both connectors and in the pump at the end of the refreeze cycle, thus assuring their proper operation in use.

Consideration was given to the use of power from the battery on the primary LSS as an alternative to the selected self-contained battery configuration. The average mission life of the Fusible Heat Sink is one hour and the primary LSS can be used for seven hours without recharging. It is advantageous to replace the Fusible Heat Sink battery simultaneously with the slurry tank every hour of the EVA rather than carry one big battery capable of supporting the primary LSS and seven Fusible Heat Sink units.

#### Configuration Considerations

**Shape:** The structural limitations on overall unit shape are minimum since the pressure buildup in the unit is limited by the accumulator. The chosen shape fits snugly against the chest or thigh and allows use of wall thicknesses that are easy to manufacture and will resist handling damage. It is impractical to manufacture and attach components to the minimum wall thickness a cylindrical shape would allow. In addition, the cylindrical shape is awkward for attaching to the suit since, for a given length, it extends further from the suit than the chosen shape.

**Mounting:** A mounting configuration utilizing separate mounting feet with alternate attachment means was rejected in favor of utilizing the inherent mechanical retention of the disconnects with a single ball lock pin providing the third mounting point. Since the ball lock pin also secures the disconnect actuation mechanism, the mounting points are thus obtained with no additional weight penalty.

**Component Location:** The battery/accumulator and the pump/motor are packaged within the slush tank to minimize the total unit volume by allowing the fluid to conform to and make use of the irregular shapes of these components. External battery and external pump/motor/battery configurations were considered but resulted in larger overall dimensions.

**Corrosion:** Materials estimated to provide adequate corrosion resistance to the slurry are utilized in all applications where slurry contact is possible. Effort is currently being expended under Contract NAS 2-8665 to experimentally verify suitable materials for slurry exposure.

## COMPONENT SELECTION

Each component of the Fusible Heat Sink has been evaluated to determine which characteristics are critical and which type of component best meets these requirements. With the exception of the brush type DC motor utilized for feasibility and functional system hardware, all components are suitable for flight hardware.

Slurry Tank

The slurry tank is the largest component of the system since it must contain 4.17 kg (9.20 lb) of slurry solution which occupies 0.00377 m<sup>3</sup> (230 in<sup>3</sup>). The slurry tank also acts as the major structural member of the system since all of the other components are attached to it. Its shape was discussed in the previous section. Although aluminum was considered as the construction material for the slurry tank to minimize weight, the computer heat transfer effort indicated that the lower conductivity of stainless steel would improve the freeze up mode. Additionally, stainless steel provides satisfactory anti-corrosion properties. Experience gained during the fusible materials investigation portion of this program has indicated that simultaneous existence of aluminum and stainless steel in combination with the slurry produces an insoluble precipitate and causes selective chemical attack to the aluminum. Perhaps coatings can be developed to protect the aluminum, but the more conservative approach is to completely eliminate aluminum from the system.

For these reasons, stainless steel has been selected as the slurry tank material.

Expansion Compensation (Accumulator)

Four types of volume expansion devices were considered for the task of limiting the pressure increase due to expansion/contraction in the system. They are as follows: closed cell foam rubber, spring loaded metal bellows, spring loaded rolling rubber diaphragm, and air filled rubber bladder. The pressure rise in the slush tank to be allowed by the device is  $6.9 \times 10^4$  Pa (10 psi) over the initial atmospheric pressure in the tank. The minimum pressure in the tank must not drop below  $5.5 \times 10^4$  Pa absolute (8 psia) to prevent vaporization of the ethanol. The closed cell foam approach has several advantages; it is resistant to damage, it can be molded to any shape, and at room temperature there is no tank pressure differential, minimizing long term leakage of the fluid. However, the spring rate of the closed cell foam is higher than an air filled bladder, requiring a larger

accumulator to accommodate the same fluid volume increase for a given pressure rise. The spring loaded metal bellows configuration has a high spring rate and exerts a constant  $6.9 \times 10^4$  Pa (10 psi) pressure on the system during room temperature storage leading to potential leakage. In addition, ice crystals that become lodged in the convolutions of the bellows will cause a significant increase in bellows spring rate that could cause a system overpressure or premature bellows failure. The spring loaded rolling diaphragm has a lower spring rate and is less sensitive to ice crystals than the metal bellows technique but is still big and heavy when compared to the air bladder technique.

The chosen expansion compensation device is the air filled rubber bladder which is the lightest and lowest volume approach to the expansion problem. It has been configured to allow the battery to be installed within the bladder, thereby optimizing the volume utilization, insulating the battery from the cold slurry, and preventing leakage of corrosive slurry into the battery case. The bladder contains  $820 \text{ cm}^3$  ( $50 \text{ in}^3$ ) of air at atmospheric pressure that acts as a spring and limits the pressure rise due to  $328 \text{ cm}^3$  ( $20 \text{ in}^3$ ) of ice expansion to  $6.9 \times 10^4$  Pa (10 psi). During room temperature storage, the bladder pressure is equal to atmospheric pressure so no air loss will occur. In operation, the  $1.01 \times 10^5$  Pa absolute (14.7 psia) charge can drop to approximately  $5.5 \times 10^4$  Pa absolute (8 psia) due to internal leakage before any performance degradation will occur. The nature of the bladder is such that there is never a significant pressure differential between the fluid and the air so that leakage of air into liquid or liquid into air is not likely.

### Battery

The battery chosen for the unit is made up of Yardney silver zinc battery cells of the same type used on the Apollo PLSS and are the obvious selection over other types of cells because of their high power densities (see Table I) and their flight proven reliability. The battery characteristics evaluated for this unit were shape, construction, location, cell arrangement, and other salient features.

The individual cells had to be chosen for the proper current capacity and connected in the proper number and order to produce power compatible with the demand of the pump/motor. Eighteen cells of type HR-1 in series produce 27 volts, allow a one ampere current drain, and provide a 1.75 ampere hour capacity as required in the selected arrangement. Several external battery locations were investigated in an attempt to thermally isolate

TABLE I  
POWER DENSITIES

<u>Battery Type</u>	<u>Watt-hours/kg</u> <u>(Watt-hours/lb)</u>	<u>Watt-hours/cm<sup>3</sup></u> <u>(Watt-hours/in<sup>3</sup>)</u>
Silver-Zinc	84.0 (38)	0.128 (2.1)
Nickel-Cadmium	28.4 (12.9)	0.085 (1.4)
Lead-Acid	22.0 (10.0)	0.073 (1.2)
Nickel-Iron	20.0 (9)	0.024 (.4)

the battery from the cold slurry to allow optimum battery operation temperature, but these locations tended to use volume inefficiently. Therefore, since an air bladder type accumulator had been chosen, it became apparent that within this air volume would be an excellent battery location because the air provides thermal isolation and allows efficient use of volume. In addition, the battery within the accumulator configuration increased the accumulator diameter requirements to the point where a single cylinder simultaneously serves as part of the slurry tank outer wall, the interior baffle, and as an effective accumulator container. A recess at the top of this cylinder offered an excellent protected location for the battery relief valve, power switch, and electrical connector.

The electrical connector serves the dual purpose of connecting the pump/motor lead wire to the battery and power switch, as well as providing recharge connection points. This technique eliminates the necessity of dual connectors or of wiring the battery and motor together permanently. During battery charging, the motor is disconnected, and reconnected once the charge cycle is completed.

The selected switch is a hermetically sealed microswitch unit. The hermetic seal configuration was chosen to prevent switch arcing from igniting any gases vented from the battery cells. To prevent overpressure of the battery case due to these vented gases, a relief valve similar to that used on the Apollo PLSS battery is included to vent the gases to ambient.

To minimize battery weight and corrosion, the battery case is made of welded thin wall stainless steel. The case is configured to provide the accumulator end plates and to accept a cylindrical rubber bladder shell bonded and clamped in place. A sealed plug in the bottom end plate allows introduction of dry air into the space between the battery and the bladder.

#### Pump/Motor

Four types of pumps were considered for the fluid transport requirement of the unit: piston, centrifugal, peristaltic, and gear. The piston pump has the potential problem of check valve hang-up on ice particles preventing pressure buildup in the pump. The centrifugal pump being a high speed, low torque type of pump has a similar potential problem of the rotor jamming on a small ice particle, thus stalling the pump. The peristaltic pump has the advantage of isolating the fluid from the moving parts of the pump and motor, thereby eliminating the need for a

magnetic coupling or dynamic seals. However, to provide adequate tube life, the unit must be run at very slow speeds necessitating the use of a motor/gearbox combination and resulting in a large pump size. In addition, the frictional losses in flexing the pump tube results in lower overall pumping efficiency requiring a larger battery and motor.

The gear type pump was finally selected since it is inherently a low speed high torque positive displacement type of pump that is capable of crushing small ice particles without stalling and of developing high system pressures to unplug an area that might become blocked with ice.

Since battery power is to be utilized, a brushless DC type motor is desirable. Various brushless type DC motors have been used for space flight programs, but none are available as low cost standard items. Therefore, to minimize cost, a brush type motor is utilized to drive the pump for the feasibility and functional system hardware. For flight hardware, a brushless DC motor would be used. To prevent leakage of slurry into the motor without the use of a dynamic seal, a magnetic coupling will be utilized. This coupling will slip and allow the motor to continue running and avoid a stall type burnout if the pump should jam.

The motor/coupling/pump combination selected for this design utilizes a commercially available Globe motor magnetically coupled to a Micropump. The pump will be tailored to provide the precise flow required and will have the internal flow pressure control bypass valve removed. The motor/coupling housing will be replaced with separate concentric motor and pump supports that mount the pump and motor to the slurry tank. The pump support also acts to seal the top of the slurry tank and to seal the pump housing, thereby preventing liquid from entering the motor and coupling area. The materials utilized in the Micropump are estimated to be suitable for slurry exposure.

#### Quick Disconnects

The quick disconnects have severe requirements in that they must pass the cooling fluid potentially containing small ice chips without impeding fluid flow, yet must seal tight and not spill fluid or take in air during separation and reconnection. A commercially available unit meeting these requirements is the Seaton Wilson "zero air" quick disconnect.

The selected disconnects have sufficient strength to act as mounting points for the package, and their ease of operation allows easy installation and removal.

### Check Valve

A Circle Seal check valve has been selected for the system. The unit selected is commercially available and has the necessary low cracking pressure and low operational pressure drop. Sensitivity to ice inclusion is not critical in this component since at start up, ethanol and warm fluid from the LCG heat exchanger will pass through the unit. The pump inlet screen limits ice particle size during operation. Reverse sealing is necessary only when the fluid is at room temperature at the start of the refreeze cycle.

### Expansion Circulation Tube

The expansion circulation tube is configured to accept the mating halves of the quick disconnects that connect to the slurry tank disconnects during freeze up operations. A resistance heating element imbedded in silicone rubber is bonded to the stainless steel tube to supply one watt of heating to prevent freezing. The connector for the heater is mounted to the tube on a bracket that extends through rigid insulation which completely encloses the tube. The insulation is shaped to allow a firm handhold during installation and removal.

### Insulation

There are two types of thermal insulation used on the Fusible Heat Sink package: rigid closed cell foam and multilayer aluminized mylar with Beta Cloth fiberglass separators and covers. The rigid foam, covered with aluminum foil tape to meet fire and outgassing criteria, is selected for use on those portions of the slurry tank that will remain insulated during the freeze up cycle; namely, the wall of the tank in the accumulator area and the portion of the tank wall closest to the pump. It is also used on the expansion circulation tube as previously mentioned. In these applications, it is molded to shape and bonded in place.

The flexible multilayer insulation is fabricated into a two piece cover similar to those used on the Apollo PLSS and OPS. Each piece of the cover will be made up of multiple layers of aluminized mylar and separators enclosed in a Beta Cloth cover and sewn together. The Beta Cloth cover is extended to cover those portions of rigid insulation that are attached to the slurry tank, thereby providing a uniform exterior appearance and minimizing convection leaks. The two parts of the cover include a removable piece that covers the sides and bottom of the slurry tanks and a fixed piece that is attached to the top of the unit to provide motor and battery insulation during freeze up operation while

allowing access to the electrical connection and switch on top of the battery by means of a movable flap. Snaps and velcro hooks and pile are used to attach the flexible insulation to the slurry tank.

### Heat Exchanger

The system LCG heat exchanger must be designed to be compatible to all the temperature/flow characteristics shown in Figure 8. A unit sized for the worst case thermal condition (end of melt cycle plus high load) must also function with no permanent freeze up at all other operating points. Actual heat exchanger conductance required for these cases varies by a factor of seven - a unit configured for Case VI would be seven times oversized for Case I. It would be very convenient if the ice layer, as it built up, added the necessary resistance or fouling factor to reduce the initial conductance to desired levels. Ice, however, has a relatively high thermal conductivity,  $2.25 \text{ J/sec-m-}^\circ\text{C}$  ( $1.3 \text{ Btu/hr-ft-}^\circ\text{F}$ ), and thicknesses required are on the order of 2.54 cm (1 in) or greater - a value more than sufficient to completely block the passages of a small volume, light weight heat exchanger. The unit design must, therefore, be permitted to freeze but configured in a manner to ensure thaw out as thermal load increases.

To meet this end, three stainless steel heat exchanger configurations were evaluated: tube in tube, tube in shell, and plate fin. Supporting calculations are presented in Appendix A.

The tube in the tube configuration is inherently the most reliable since it has the least braze or weld length (only the ends of each tube). It has one serious drawback, however, freeze up. An assembly was sized to meet the thermal requirements of Case VI consisting of a 0.318 cm (0.125 in) tube within a 0.846 cm (0.333 in) tube. The core weight for this configuration is 0.22 kg (0.46 lb).

We have selected a maximum value of 6,880 Pa (1.0 psi) for the LCG pressure drop through the heat sink - a value similar to current Apollo hardware. For the tube in tube configuration, an achieved pressure drop of 1,307 Pa (0.19 psi) will be experienced with one 1.47 m (4.82 ft) length of tubing. This value is well within the design requirement. Freeze up is a severe problem with the inlet tube configuration. At low heat loads, complete pluggage of the passage is predicted, and thaw out is virtually impossible. Thus, this configuration will not satisfy the system requirements.



Case	Heat Load Joule/s (Btu/hr)	T <sub>1</sub> °C (°F)	T <sub>2</sub> °C (°F)	T <sub>3</sub> °C (°F)	T <sub>4</sub> °C (°F)	T <sub>5</sub> °C (°F)	W <sub>1</sub> g/s (lb/min)	W <sub>3</sub> g/s (lb/min)	W <sub>5</sub> g/s (lb/min)	Start/ End
I	117.3 (400)	22 (71.7)	0 (32)	-14.3 (6.2)	-13.3 (8.1)	21.1 (70)	1.29 (.17)	30.2 (4)	30.2 (4)	S
II	117.3 (400)	22 (71.7)	0 (32)	-7.3 (18.8)	-6.3 (20.7)	21.1 (70)	1.29 (.17)	30.2 (4)	30.2 (4)	E
III	440 (1500)	16.8 (62.3)	0 (32)	-14.3 (6.2)	-10.3 (13.5)	13.3 (56)	6.27 (.83)	30.2 (4)	30.2 (4)	S
IV	440 (1500)	16.8 (62.3)	0 (32)	-7.3 (18.8)	-3.3 (26.1)	13.3 (56)	6.27 (.83)	30.2 (4)	30.2 (4)	E
V	586.6 (2000)	14.6 (58.3)	0 (32)	-14.3 (6.2)	-8.9 (15.9)	10.0 (50)	9.83 (1.3)	30.2 (4)	30.2 (4)	S
VI	586.6 (2000)	14.6 (58.3)	10.0 (50)	-7.3 (18.8)	-1.9 (28.5)	10.0 (50)	30.2 (4.0)	30.2 (4)	30.2 (4)	E

Fluid specific heat estimated as 3.6 J/g-°C (0.86 Btu/lb-°F)




FIGURE 8 SYSTEM TEMPERATURE/FLOW CHARACTERISTICS

Utilizing the standard compact tube and shell configuration, a unit was sized containing 0.318 cm (1/8 in) tubes 4.45 cm (1.75 in) long. The flow is one pass shell and one pass tube side and is contained within a 7.62 cm (2.25 in) O.D. shell. With this concept, tubes will freeze progressively until only that number required to meet low loads (approximately 20 tubes) is still open and passing flow. As heat load increases, however, the cold and frozen tubes surrounded by the slurry solution cannot be thawed. There is no practical manner in which heat can be supplied to these isolated areas to stimulate thaw. The concept, although providing an excellent approach to satisfy the high load requirements, does not appear feasible for a freeze - thaw application. The core weight for this configuration is 0.281 kg (0.63 lb). Pressure drop is less than 700 Pa (0.1 psi).

A plate fin heat exchanger configured to meet the fusible heat sink requirements would be similar to that shown in Figure 9. The concept is a three fluid device containing passages for fusible sink slurry flow, LCG water to be cooled, and heat exchanger LCG bypass flow. Dense, ruffled fins in the main heat exchanger are sized to meet the high load requirements of Case VI (Figure 8). Within the bypass circuit, only the minimum fin density compatible to core structural requirements is employed to minimize heat transfer area. The same criteria will be applied to the fusible sink flow.

At maximum load conditions, the majority of the LCG flow is directed through the heat exchanger with only a minor fraction through the bypass. At minimum load, the condition reversed, and the bypass is handling all or most of the flow. The water in the core freezes under this condition, but that portion of the core adjacent to the bypass remains warm and open to flow. As the heat load increases, flow through the system is diverted to the core, and a thaw out process is initiated. Because all portions of the LCG circuit are adjacent to the warm fluid, the thaw boundary will progress until that portion of the assembly required for heat transfer is available.

The heat exchanger incorporates several features to improve overall system performance. First, the slurry inlet and outlet contain the mating halves of the zero-spill disconnects so that no additional line runs are required, minimizing leakage potential. Second, one of the heat exchanger end plates extends to interface with the EVA suit and seals to the suit pressure bladder, thus providing a suit mounting point for the Fusible Heat Sink. And third, the LCG inlet and outlet ports of the heat exchanger are located inside the suit, and the Fusible Heat Sink inlet and outlet ports are located outside the suit so that no cooling lines need penetrate the suit pressure bladder.




FIGURE 9: PLATE FIN HEAT EXCHANGER CORE

## WEIGHT SUMMARY

The weight of every item in the Fusible Heat Sink System has been calculated, measured, or estimated in order to provide as accurate a weight as possible for evaluation of the proposed design concept. As the sample calculations show, each item is broken down into elemental form for an accurate volume calculation and then multiplied by the material density to establish a weight. The calculated weight of all items is then totaled. A five percent margin for manufacturing tolerances is then added to account for an approximate two sigma spread on stock thicknesses. This five percent margin has proven accurate in previous calculated item weights. Normally at the concept level of definition of an item, an additional 5 or 10% growth margin would be added to account for possible additions necessary in defining the final layout design weight. However, in the case of the Fusible Heat Sink System concept, the proposed design has been exercised to the point where no additional margin is necessary to predict the weight of the hardware that can be manufactured to this design. This does not preclude the possibility of weight changes to the design, either increases or decreases, that are deemed necessary or desirable after actual hardware testing has been accomplished.

Table II shows a summary of all calculated weights and a total representative of the final design weight of the Fusible Heat Sink. The weights of the Heat Sink, the heat exchanger, and the expansion circulation tube are shown separately since different numbers of each will be carried on board a Shuttle flight. For instance, there will be only as many heat exchangers as there are suits on board. There will be only as many expansion circulation tubes on board as there are Heat Sink spaces in the freezer chest since the tubes are interchangeable between units. Finally, there will be as many Heat Sinks on board as proposed EVA missions require; namely, one Heat Sink per 1.33 EVA man-hours expected to be required in any 30 hour period (24 hour freeze up time plus 6 hours contingency for handling units). Thus, the total flight weight of the Fusible Heat Sink depends on the discretion of the mission planners.

All weights have been calculated in pounds and converted to kg for international units.

TABLE II  
CALCULATED WEIGHT SUMMARY

	<u>kg</u>	<u>(lbs)</u>
<u>Fusible Heat Sink</u>		
Slurry Tank	2.37	(5.22)
Battery and Accumulator	1.93	(4.25)
Pump/Motor and Accessories	1.17	(2.58)
Check Valve	0.09	(0.2)
Disconnect Halves	0.17	(0.38)
Disconnect Latch Release	0.38	(0.84)
Thermal Insulation	0.24	(0.52)
Heat Sink Fluid	<u>4.17</u>	<u>(9.20)</u>
TOTAL HEAT SINK WEIGHT	10.52	(23.19)
<u>LCG Heat Exchanger</u>		
Core	0.46	(1.02)
Headers	0.20	(0.45)
Disconnect Halves	0.04	(0.09)
Fluids	<u>0.86</u>	<u>(1.89)</u>
TOTAL HEAT EXCHANGER WEIGHT	1.56	(3.45)
<u>Expansion Circulation Tube</u>		
Tube Assembly and Disconnect Halves	0.10	(0.22)
Heater and Connector	0.04	(0.08)
Insulation	0.05	(0.11)
Fluid	<u>0.17</u>	<u>(0.37)</u>
TOTAL EXPANSION CIRCULATION TUBE WEIGHT	0.36	(0.78)

## SAMPLE WEIGHT CALCULATIONS - PUMP/MOTOR

Pump and Motor from Mircopump

$$\text{weight} = 720 \text{ gms} \times 0.00205 \text{ lb/gm} = + 1.587$$

Less Coupling Enclosure

$$67.7 \text{ gms} \times 0.00205 \text{ lb/gm} = - 0.139$$

Plus Screen

$$\left[ \left( \pi \times 1.8 \times 2.3 + \pi \times 1.82^2/4 \right) (20 + 20) \times \pi \times 0.012^2/4 + \pi \times 1.9 \times 0.04 \times 0.5 \right] \times 0.3 = + 0.050$$

Plus Disconnect Adaptor

$$\pi (1.65 \times 0.5 \times 0.18 + 1.2 \times 0.08 \times 1.0 + 0.8 \times 0.4 \times 0.13 + 0.5 \times 0.1 \times 0.5 + 0.25 \times 0.1 \times 0.4) \times 0.3 = + 0.303$$

Plus Pump Support

$$\pi (2.0 \times 4.0 \times 0.1 + 3.3 \times 0.4 \times 0.15 + 3.0 \times 1.0 \times 0.1) \times 0.08 = + 0.326$$

Plus Motor Support

$$\pi (1.3 \times 0.6 \times 0.1 + 1.8 \times 0.1 \times 2.2 + 3.0 \times 0.1 \times 0.1) \times 0.08 = + 0.194$$

Plus Metal Rings

$$\pi (1.4 \times 0.4 \times 0.05 + 1.2 \times 0.4 \times 0.05 \times 3.7 \times 0.5 \times 0.05) \times 0.3 = + \underline{0.136}$$

Total Calculated Weight

$$2.457$$

Plus 5% for tolerance

$$+ \underline{.123}$$

Estimated Pump/Motor Weight at Concept Level

$$2.580 \text{ lb}$$

### PERFORMANCE ANALYSIS

A math model of the Fusible Heat Sink has been constructed and utilized in support of the preliminary design effort described in the previous section. Specific objectives of the analysis were aimed at describing the sink cool down and thaw out processes to ensure proper functioning during these critical periods.

### RECHARGE MODE OPERATION

A study was undertaken to (1) determine the temperature history of the Fusible Heat Sink as it cools to a completely frozen or slurry condition while being refrigerated, and (2) to determine the LCG heat exchanger inlet temperature while fluid is being circulated between the heat exchanger and the Fusible Heat Sink with the LCG heat exchanger absorbing metabolic load.

During cool down and freeze, the Fusible Heat Sink exhibits a net increase in volume accounted for in the design by an expansion compensation device. Expansion in the main reservoir is relieved as fluid or slurry passes through the pump to the expansion circulation tube which discharges into the accumulator. Two factors are utilized to ensure that this flow path remains open during cool down:

- As water is frozen out of solution, the remaining liquid is enriched in ethanol, thus lowering the freezing point. Therefore, the fluid flowing through the tube is also continually increasing in alcohol content.
- The system design should be such that the flow area temperatures should remain above  $-14.3^{\circ}\text{C}$  ( $6.2^{\circ}\text{F}$ ) until regeneration is complete.

A simplification of this process has been used as the criteria for the math model. Our aim has been to ensure that the expansion system remains warmer than the heat sink reservoir during the entire cool down period. The initial cases run with the thermal model indicated that this was not happening. To explain this, it is necessary to understand that the time for a part to cool is related to its thermal mass and its conductance to the driving temperature (the heat sink). The property of a part that defines the time for a part to change temperature is called the time constant which is defined as  $mc_p / \Sigma G$ ; where  $mc_p$  is the thermal mass of the part, and  $\Sigma G$  is the sum of the conductances to adjacent parts. The larger the time constant, the longer it takes for a part to reach equilibrium. Because of the large latent energy associated with the heat sink, the effective thermal mass and its time constant are quite large compared to those areas which

do not contain solution. Cool down time for the sink was, therefore, much longer than the accumulator. Corrective action would not be directed toward the thermal mass - this is a constant in the analysis - but toward the conductance to the heat sink. Conductance to the heat sink had to be increased, thus reducing the time constant while flow section time constants were increased by reducing conduction to the environment. In actual practice, this will be achieved by insulating to slow cooling and by increasing convection (such as by fan-forced air) to increase cooling.

A 30 node thermal model was prepared to describe this cooling transient case. The model is described in Appendix B and includes 13 fluid nodes in addition to nodes on the insulation, tank metal, battery, and pump. Conductances were calculated between internal connecting nodes and for connections to the environment for those nodes on the outside of the package.

In programming the cooling model, several assumptions were made. The total heat released, due to heat of fusion and solution from the Fusible Heat Sink is 512 J/g (220 Btu/lb). It was assumed that this heat is released over the temperature range of  $-14.3^{\circ}\text{C}$  ( $6.2^{\circ}\text{F}$ ) to  $-7.3^{\circ}\text{C}$  ( $18.8^{\circ}\text{F}$ ). In order to facilitate this in the program, the fluid specific heat was defined as  $220/(18.8-6.2)$ , or  $73.3 \text{ J/g-}^{\circ}\text{C}$  ( $7.5 \text{ Btu/lb-}^{\circ}\text{F}$ ) for this temperature range. A value of  $3.35 \text{ J/g-}^{\circ}\text{C}$  ( $0.8 \text{ Btu/lb-}^{\circ}\text{F}$ ) was used for temperatures above  $-7.3^{\circ}\text{C}$  ( $18.8^{\circ}\text{F}$ ).

Above a temperature of  $-7.3^{\circ}\text{C}$  ( $18.8^{\circ}\text{F}$ ), the thermal conductivity of the solution was assumed to be  $0.0065 \text{ W/cm-}^{\circ}\text{C}$  ( $0.375 \text{ Btu/hr-ft-}^{\circ}\text{F}$ ). This was increased linearly with decreasing temperature to a value of  $0.0225 \text{ W/cm-}^{\circ}\text{C}$  ( $1.3 \text{ Btu/hr-ft-}^{\circ}\text{F}$ ) over the range from  $-7.3^{\circ}\text{C}$  ( $18.8^{\circ}\text{F}$ ) to  $-14.3^{\circ}\text{C}$  ( $6.2^{\circ}\text{F}$ ). The higher figure is the thermal conductivity of ice at  $0^{\circ}\text{C}$  ( $32^{\circ}\text{F}$ ).

The outer surface of insulation releases heat to the cold surroundings at  $-17.8^{\circ}\text{C}$  ( $0^{\circ}\text{F}$ ) by radiation and convection. The emissivity used at the outer insulation surfaces was 0.05 (gold or aluminum foil). The view factor was taken as 1.0, as it was for all other radiation conductors. Radiation conductors from the tank surface have an emissivity of 1.0. Convective heat transfer was increased to the bare metal surfaces of the heat sink nodes and not to the insulation where the heat transfer rate was held to natural convection at  $h = 5.67 \times 10^{-4} \text{ W/cm}^2\text{-}^{\circ}\text{C}$  ( $1.0 \text{ Btu/hr-ft}^2\text{-}^{\circ}\text{F}$ ).



Metal parts of the package were assumed to be stainless steel having a thermal conductivity of  $0.147 \text{ W/cm-}^\circ\text{C}$  ( $8.5 \text{ Btu/hr-ft-}^\circ\text{F}$ ). An insulation conductivity of  $3.5 \times 10^{-4} \text{ W/cm-}^\circ\text{C}$  ( $0.02 \text{ Btu/hr-ft-}^\circ\text{F}$ ) was also used. The insulation thickness was held to  $1.27 \text{ cm}$  ( $0.5 \text{ inches}$ ).

The motor was modeled with a plastic sleeve, mounted from the top of the cover to the lower portion of the magnetic coupling so that only the lower portion of the pump is in direct contact with fluid.

A heater less than 1 watt is required for the disconnect tube to prevent preliminary freeze. This was simulated in the model by putting the dissipated power directly into the metal tube.

Analytical results are shown in Figures 10 through 17 for the cool down model. Figure 10 shows a typical transient profile, while Figure 11 shows total energy removal versus cool down time. Figures 12, 13, and 14 show nodal temperatures after 10 hours of cooling, while Figures 15, 16, and 17 reflect 30 hours of cooling.

#### NORMAL MODE OPERATION

The warm-up model differs somewhat from the cool down model and is described in Appendix B. The expansion circulation tube is missing along with tube fluid and tube insulation. The warm-up model includes a fluid node in the pump,  $16.4 \text{ cm}^3$  ( $1 \text{ in}^3$ ), and in the external loop,  $81.9 \text{ cm}^3$  ( $5 \text{ in}^3$ ). Two additional insulation nodes are included so that the package is entirely covered with insulation. Heat is added to the fluid in the external loop to simulate the heat input from the LCG heat exchanger. Flow conductors connect the outside fluid loop to the fluid flowing within the Fusible Heat Sink package.

The flow rate is  $108.9 \text{ kg/hr}$  ( $240 \text{ lb/hr}$ ). The warm-up model was run for heat exchanger loads of  $422$ ,  $1,583$ , and  $2,100 \text{ kJ/hr}$  ( $400$ ,  $1,500$ , and  $2,000 \text{ Btu/hr}$ ). The pump motor power is  $27 \text{ W}$  ( $92.1 \text{ Btu/hr}$ ). This power was put into the pump/motor node. The fluid in the pump was connected to the pump with a suitable conductance value. Figure 18 shows the results of this analysis which indicates that pump outlet temperature is maintained below  $0^\circ\text{C}$  ( $32^\circ\text{F}$ ) for one hour with a heat exchanger load of  $2,100 \text{ kJ/hr}$  ( $2,000 \text{ Btu/hr}$ ) in the external fluid circulation loop.

#### SUMMARY

Two thermal models were prepared for use as a tool to describe the thermal effects of physical changes to the Fusible Heat Sink. The cool down model shows the temperature response of the package while the package is being refrigerated. The second, warm-up,

CURVES BASED ON:  $h = 1.7 \times 10^{-3} \text{ W/cm}^2\text{-}^\circ\text{C}$  (3 Btu/hr-ft<sup>2</sup>-°F) TO UNINSULATED SECTIONS  
ENVIRONMENT TEMPERATURE = -17.8°C (0°F)




FIGURE 10: THERMAL RESPONSE OF FUSIBLE HEAT SINK DURING COOLDOWN







FIGURE 11: FUSIBLE HEAT SINK - COOLDOWN CONDITION




 Indicates Node Numbers

FIGURE 12: FUSIBLE HEAT SINK COOLDOWN  
SIDE VIEW - TIME = 10 HOURS




FIGURE 13: FUSIBLE HEAT SINK COOLDOWN  
EXPANSION CIRCULATION TUBE - TIME = 10 HOURS




FIGURE 14: FUSIBLE HEAT SINK COOLDOWN  
TOP VIEW - TIME = 10 HOURS




FIGURE 15: FUSIBLE HEAT SINK COOLDOWN  
SIDE VIEW - TIME = 30 HOURS




FIGURE 16: FUSIBLE HEAT SINK COOLDOWN  
EXPANSION CIRCULATION TUBE - TIME = 30 HOURS






FIGURE 17: FUSIBLE HEAT SINK COOLDOWN  
TOP VIEW - TIME = 30 HOURS




FIGURE 18: FUSIBLE HEAT SINK WARMUP CONDITION  
PUMP OUTLET TEMPERATURE VERSUS TIME

model shows the temperature response of the package while warmed fluid is being circulated to it from the LCG heat exchanger loop. The results of this study show that critical areas of the heat sink package must be thermally isolated from the  $-17.7^{\circ}\text{C}$  ( $0^{\circ}\text{F}$ ) refrigerant to ensure free flow pumping at minimum package temperatures. Conversely, to attain reasonable cool down or recharge time, the thermal conductance between the refrigerant and heat sink must be maximized. The model has shown that the areas to be insulated include the entire battery section, the top of the motor section, and a section of the motor (reservoir) section where the pump is closest to the side wall. Additionally, the cool down time can be significantly decreased by adding internal fins to the slurry tank, and by supplying forced air circulation within the freezer or clamping the slurry tank directly to the freezer wall.

In the operational or warm-up mode, the pump discharge fluid temperature remains below  $0^{\circ}\text{C}$  ( $32^{\circ}\text{F}$ ) while providing a total available heat sink of 2,110 kJ (2,000 Btu).

COMPONENT AND SYSTEM SPECIFICATIONS

## SYSTEM SPECIFICATION

Performance - A detailed system performance specification is included in the Preliminary Design section of this report.

Operating Temperature -  $-17.8^{\circ}\text{C}$  ( $0^{\circ}\text{F}$ ) to  $21.1^{\circ}\text{C}$  ( $70^{\circ}\text{F}$ )

Envelope - The system exclusive of the suit mounted heat exchanger shall not exceed the following envelope: 30.5 cm (12 in) high x 26.7 cm (10.5 in) wide x 14.0 cm (5.5 in) deep. The heat exchanger shall not exceed the following envelope: 17.8 cm (7.0 in) long x 16.0 cm (6.3 in) wide x 3.6 cm (1.4 in) deep, including headers.

Weight - The system exclusive of the suit mounted heat exchanger shall not exceed the following weight: 10.52 kg (23.19 lb) wet, 6.35 kg (13.99 lb) dry. The heat exchanger shall not exceed the following weight: 1.56 kg (3.45 lb) wet, 0.70 kg (1.56 lb) dry.

Vehicle Interfaces - A freezer with internal dimensions no less than 30.5 cm x 26.7 cm x 14.0 cm (12 in x 10.5 in x 5.5 in), and an internal temperature of  $-17.8^{\circ}\text{C}$  ( $0^{\circ}\text{F}$ ) is required for refreeze of the slurry. Additionally, two 27 VDC electrical connectors are required for battery recharge at 0.1 ampere maximum and for expansion tube heating at 0.037 ampere.

Suit Interface - The LCG heat exchanger mounts on a suitable portion of the suit where it penetrates the pressure shell and mates with the inlet and outlet lines from the LCG. No other suit interfaces are required.

External Leakage - There shall be no measurable external leakage when the system is pressurized with water to a pressure of 69 kPa delta (10 psid).

## COMPONENT SPECIFICATIONS

Detail specifications for the components that make up the system are presented in this section. Figure 7 shows a detail cross section of all components, except the heat exchanger which is shown in Figure 19.




FIGURE 10: LIQUID COOLING GARMENT HEAT EXCHANGER CONCEPT

Slurry Tank Specification

Performance - The slurry tank shall be constructed to contain  $3,700 \text{ cm}^3$  ( $230 \text{ in}^3$ ) of potassium bifluoride-water-ethanol solution. In addition, the tank shall have sufficient volume to contain internally the following items:

- Pump/Motor
- Battery
- Accumulator
- Inlet and Outlet Disconnect
- Check Valve

The tank shall contain mounting provisions for these components and shall provide a separate chamber for the accumulator to which the inlet disconnect and check valve can be attached. The tank shall be covered with molded rigid closed cell insulating foam in the areas shown on Figure 19, with aluminum foil tape covering exposed foam surfaces.

The tank shall be capable of withstanding a proof pressure of 258 kPa (37.5 psig) and a burst pressure of 345 kPa (50 psig).

Operating Temperature -  $-17.8^\circ\text{C}$  ( $0^\circ\text{F}$ ) to  $21.1^\circ\text{C}$  ( $70^\circ\text{F}$ )

Envelope - The tank shall not exceed the following envelope:  
 $30.5 \text{ cm} \times 25.4 \text{ cm} \times 12.7 \text{ cm}$  (12 in x 10 in x 5 in).

Weight - The tank shall not weigh more than 2.37 kg (5.22 lb).

Interfaces - The tank shall utilize the two female disconnects as two of three mounting points and shall provide a means of actuating those disconnects from an accessible position by a suited astronaut. The third mounting point shall be a ball lock pin equally accessible. Actuation of the disconnects shall not be possible until the ball lock pin has been removed.

Construction - The tank shall be constructed of welded stainless steel.

External Leakage - There shall be no measurable external leakage utilizing water at a pressure differential of 69 kPa (10 psi).

Internal Leakage - Leakage between the tank interior and the accumulator chamber shall not exceed  $1.25 \times 10^{-5} \text{ g/s}$  ( $10^{-4} \text{ lb/hr}$ ) of water with the tank pressurized 69 kPa (10 psi) greater than the chamber.

### Accumulator Specification

Performance - The accumulator shall be a rubber bladder enclosed air volume capable of absorbing 327.7 cm<sup>3</sup> (20 in<sup>3</sup>) of slurry tank volume expansion without exceeding 69 kPa (10 psi) pressure increase. The bladder shall contain dry air at -20°C (-4°F) dew point, 21.1°C (70°F) dry bulk at 101 kPa absolute (14.7 psia) in the uncompressed state.

Operating Temperature - -17.8°C (0°F) to 21.1°C (70°F)

Envelope - The accumulator envelope shall not exceed 10.16 cm (4 in) diameter x 20.3 cm (8 in) length. Note: Battery may be partially contained within this volume.

Weight - The accumulator shall not weigh more than 0.10 kg (0.22 lb).

Interfaces - The accumulator shall be constructed as an integral part of the battery case. An "O" ring sealed port shall be provided to allow repressurization of the air in the accumulator bladder.

Construction - The accumulator bladder shall be silicon rubber. Stainless steel clamps and a suitable adhesive shall attach the bladder to the battery interface.

External Leakage - There shall be no measurable external leakage utilizing water at a pressure differential of 69 kPa (10 psi).

Internal Leakage - Leakage between the accumulator chamber and the tank interior shall not exceed  $1.25 \times 10^{-5}$  g/s ( $10^{-4}$  lb/hr) of water with the chamber pressurized 69 kPa (10 psi) greater than the tank.

### Battery Specification

Performance - The battery shall provide 36 watt hours of energy for a D.C. motor at 27 VDC and 1 ampere maximum current draw. The battery shall contain a hermetically sealed switch and an electrical connector as shown on Figure 19. The battery case shall provide a relief valve to prevent case pressure from exceeding 172 kPa (25 psig). The battery shall provide mounting provisions for the accumulator and shall be partially contained therein.

Operating Temperature - -17.8°C (0°F) to 21.1°C (70°F)

Envelope - The battery with accumulator attached shall not exceed 10.16 cm (4 in) diameter x 25.4 cm (10 in) length.

Weight - The battery with accumulator attached shall not exceed 1.83 kg (4.03 lb).

Interfaces - The battery shall provide a single electrical connector for interface with the unit pump/motor and for battery recharge. The battery switch shall be located where it is accessible to a suited astronaut. The battery shall be mounted to the slurry tank and provide an external seal to the accumulator chamber.

Construction - The battery shall be of welded stainless steel construction.

External Leakage - There shall be no measurable external leakage utilizing water at a pressure differential of 69 kPa (10 psi).

#### Pump/Motor Specification

Performance - The pump/motor combination shall consist of a brush type D.C. motor magnetically coupled to a gear type pump supported in such a way as to expose the motor and coupling to ambient air while the pump is immersed in the slurry tank fluid. The pump shall flow 30.2 g/s (4 lb/min) of slurry tank fluid against a pressure head of 27.5 kPa (4 psi) maximum. The maximum motor power shall be 27 watts at 27 VDC.

Operating Temperature - -17.8°C (0°F) to 21.1°C (70°F)

Envelope - The pump/motor and supports shall not exceed 11.43 cm (4.5 in) diameter x 16.51 cm (6.5 in) length.

Weight - The pump/motor assembly shall not exceed 1.17 kg (2.58 lb).

Interfaces - The pump/motor support shall interface with and seal the top of the slurry tank at the outlet disconnect location. The pump/motor assembly shall provide a type MS33649-4 boss for attachment of the outlet disconnect. The pump/motor assembly shall provide a 7.9 x 7.9 per cm (20 x 20 per in) mesh screen at the pump inlet. The pump/motor assembly shall provide an electrical connector with a 12.7 cm (5 in) lead for connection with the battery.

Construction - The motor and coupling shall be of unrestricted construction. The pump shall be of stainless steel and teflon construction. The pump and motor supports shall be Kel-F-81 plastic.



External Leakage - The external leakage of the pump shall not exceed  $1.25 \times 10^{-4}$  g/s ( $10^{-3}$  lb/hr) water at 27.5 kPa (4 psig).

Internal Leakage - The nonoperating reverse flow internal leakage of the pump shall not be less than 0.063 g/s (0.05 lb/hr) water with a 6.9 kPa (1 psi) pressure differential.

### Disconnect Specification

Performance - The disconnect shall be of the zero-spill configuration and shall have a maximum water spillage or air inclusion of  $16.39 \times 10^{-5}$  cm<sup>3</sup> ( $1 \times 10^{-5}$  in<sup>3</sup>) per cycle. The connection force shall not exceed 4.54 kg (10 lb). The pressure drop shall not exceed 3.45 kPa (0.5 psi) with a slurry tank fluid flow of 30.2 g/s (4 lb/min). The external leakage from either half of the disconnect when engaged or disengaged shall not exceed 0.000125 g/s (0.001 lb/hr) water at 103 kPa at 15 psig pressure.

Operating Temperature - -17.8°C (0°F) to 21.1°C (70°F)

Envelope - The envelope of the female half of the disconnect shall not exceed 3.05 cm (1.2 in) diameter x 6.35 cm (2.5 in) long, and the envelope of the male half shall not exceed 2.54 cm (1 in) diameter x 5.08 cm (2.0 in) long.

Weight - The weight of the disconnect halves shall not exceed 0.02 kg (0.045 lb) for one male half and 0.85 kg (0.19 lb) for one female half.

Interfaces - The disconnects shall have a type MS33656E4 port on one end and shall be compatible with the mating half at the other end.

Construction - The disconnects shall be of stainless steel construction with elastomer seals.

External Leakage - There shall be no measurable external leakage utilizing water at a pressure differential of 69 kPa (10 psi).

### Check Valve Specification

Performance - The check valve shall flow 30.2 g/s (4 lb/min) of slurry tank fluid in the flow direction without exceeding 3.45 kPa (0.5 psi) pressure drop. Reverse flow leakage shall not exceed 0.0000125 g/s (0.0001 lb/hr) at 0.138 kPa (0.02 psi) pressure differential.

External Leakage - There shall be no measurable external leakage utilizing water at a differential of 69 kPa (10 psi).

### Insulation Blanket Specification

Performance - The insulation blanket shall completely enclose the assembled slurry tank and in conjunction with the rigid insulation on the tank shall limit the heat transfer from the tank at a temperature differential of 36°C (65°F) in a one 'g' environment to a maximum of 14.66 J/s (50 Btu/hr). The blanket shall be configured as shown on Figure 19 and shall be removable for freeze up mode operation. Access by a suited astronaut shall be provided to the battery switch and recharge connector during operation.

Operating Temperature - -17.8°C (0°F) to 21.1°C (70°F)

Envelope - The insulation blanket shall conform to the exterior of the slurry tank and shall not exceed 1.27 cm (0.5 in) thickness.

Weight - The weight of the insulation blanket shall not exceed 0.24 kg (0.52 lb).

Interfaces - The insulation blanket shall interface with the slurry tank.

Construction - The insulation blanket for the flight prototype unit shall be constructed of 20 layers aluminized mylar with fiber glass Beta cloth separators and cover. Velcro hook and pile, and snaps shall be used to provide removability and access. In the areas where fixed insulation is attached to the slurry tank, only cover material, no mylar and separators, shall be used. The feasibility and functional system hardware will incorporate an insulation blanket that duplicates the thermal performance of the flight prototype blanket but is constructed of less exotic and costly materials.

### Heat Exchanger Specification

Performance - The heat exchanger shall be sized to transfer a maximum of 586.6 J/s (2,000 Btu/hr) from slurry tank fluid flowing at 30.2 g/s (4 lb/min) and -7.3°C (18.8°F) to the LCG water loop flowing at 30.2 g/s (4 lbs/min) and 14.6°C (58.3°F). The heat exchanger shall be of a configuration that allows operation after partial freezing of the LCG water flow passes due to low heat load operation of 117.3 J/s (400 Btu/hr) with the slurry tank fluid at -14.3°C (6.2°F) and 30.2 g/s (4 lb/min) and the LCG water flow at 22°C (71.2°F) and 30.2 g/s (4 lb/min). The

heat exchanger shall contain two male disconnect halves to interface with the slurry tank. The pressure drop through either loop shall not exceed 6.89 kPa (1 psi) at 30.2 g/s (4 lb/min) flow. The heat exchanger shall be capable of withstanding a proof pressure of 258 kPa (37.5 psig) and a proof pressure of 345 kPa (50 psig).

Operating Temperature - -17.8°C (0°F) to 21.1°C (70°F)

Envelope - The heat exchanger shall not exceed an envelope of 17.8 cm x 12.2 cm x 0.76 cm (7.0 in x 4.8 in x 0.3 in) exclusive of inlet/outlet bosses and 17.8 cm x 16.0 cm x 3.6 cm (7.0 in x 6.3 in x 1.4 in) with bosses and disconnects included.

Weight - The heat exchanger weight shall not exceed 1.56 kg (3.45 lb) wet or 0.70 kg (1.56 lb) dry.

Interfaces - The heat exchanger shall have 0.952 cm (0.375 in) beaded tube ends for interface with the LCG loop, and male half disconnects for interface with the slurry tank. The heat exchanger shall have provisions for interfacing with the pressure bladder wall of the space suit with the LCG interfaces inside the suit and the disconnect interfaces outside the suit.

Construction - The heat exchanger shall be of stainless steel plate fin construction with a brazed core and headers attached by welding.

External Leakage - There shall be no measurable external leakage utilizing water at a pressure differential of 69 kPa (10 psi) in any direction.

Internal Leakage - There shall be no internal leakage between the LCG loop and the slurry loop utilizing water at a pressure differential of 69 kPa (10 psi) in any direction.

APPENDIX A  
SUPPORTING HEAT  
EXCHANGER CALCULATIONS

Heat Exchanger Sizing

High load, end of mission (Case VI)

$$LMTD = \frac{(50-18.8) - (58.3-28.5)}{\ln \frac{(50-18.8)}{(58.3-28.5)}} = 30.5^{\circ}\text{F}$$

$$UA_{\text{req'd}} = \frac{Q}{LMTD} = \frac{2000 \text{ Btu/hr}}{30.5^{\circ}\text{F}}$$

$$= 66 \frac{\text{Btu}}{\text{hr-}^{\circ}\text{F}}$$

Low load, start of mission (Case I)

$$LMTD = \frac{(71.7-8.1) - (32-6.2)}{\ln \frac{(71.7-8.1)}{(32-6.2)}} = 42.5^{\circ}\text{F}$$

$$UA_{\text{req'd}} = \frac{400}{42.5} = 9.4 \frac{\text{Btu}}{\text{hr-}^{\circ}\text{F}}$$

Can ice thickness provide this reduction in heat exchanger conductance?

$$\frac{1}{UA_{\text{req'd low}}} = \frac{1}{UA_{\text{req'd high}}} + \text{Ice Resistance}$$

$$\frac{1}{9.4} = \frac{1}{66} + \frac{\Delta X}{KA}$$

$$\Delta X = [.106 - .015](1.3)A$$

$$= .118A$$

$$\text{Assume } A \approx .5\text{ft}^2$$

$$\Delta X = (.118)(.5)(12 \frac{\text{in}}{\text{ft}})$$

$$= .7 \text{ inch}$$

Too thick for practical application!

Tube in Tube Heat Exchanger

Inner tube: O.D. = 0.125"

I.D. = 0.099"

Outer tube: I.D. = 0.333"

Water flow in annulus:

$$De = \frac{\frac{\pi}{4} (.333^2 - .125^2)}{\pi (.333 + .125) (12)} = 0.017 \text{ ft}$$

$$G = \frac{W}{A}$$

$$= \frac{240 \text{ lbs/hr}}{\frac{\pi}{4} (.333^2 - .125^2)} \times 144 \frac{\text{in}^2}{\text{ft}^2}$$

$$= 461,908 \frac{\text{lb}}{\text{hr-ft}^2}$$

$$NRe = \frac{DeG}{\mu}$$

$$= \frac{(.017) (461,908)}{(3.1)} = 2533$$

$$\frac{hDe}{K} = .023 (NRe)^{.8} \left( \frac{CP\mu}{K} \right)^{.4}$$

$$h_{An} = \frac{(.023) (.332)}{(.017)} (2533)^{.8} \left( \frac{(1.0) (3.1)}{.332} \right)^{.4}$$

$$= 580 \frac{\text{Btu}}{\text{hr-ft}^2-\text{°F}}$$

Slurry flow in tube:

$$De = \frac{.099}{12} = .00825 \text{ ft}$$

$$G = \frac{W}{A}$$

$$= \frac{240}{\frac{\pi}{4} (.099)^2} \times 144 = 4489660 \frac{\text{lb}}{\text{hr-ft}^2}$$

$$N_{Re} = \frac{DeG}{\mu}$$

$$= \frac{(.00825)(4489660)}{(12.1)} = 3061$$

$$\frac{hDe}{K} = .023 (N_{Re})^{.8} \left( \frac{CP\mu}{K} \right)^{.4}$$

$$h_{\text{tube}} = \frac{.023(.26)}{.00825} (3061)^{.8} \left( \frac{(.785)(12.1)}{(.26)} \right)^{.4}$$

$$= 1879.4 \frac{\text{Btu}}{\text{hr-ft}^2-\text{°F}}$$

$$\frac{1}{UA_{\text{req'd}}} = \frac{1}{h_{An}A_{An}} + \frac{1}{h_{\text{tube}}A_{\text{tube}}}$$

$$\frac{1}{66} = \frac{1}{(580) \frac{\pi(.125)L}{12}} + \frac{1}{1879.4 \frac{\pi(.099)L}{12}}$$

$$.0152 = \frac{.0527}{L} + \frac{.02053}{L}$$

$$L = 4.82 \text{ ft}$$

Calculate water pressure drop:

$$V = \frac{G}{\rho}$$

$$= \frac{461,908}{(62.4)} (3600 \text{ sec/hr})$$

$$= 2.06 \frac{\text{ft}}{\text{sec}}$$

$$f = .006 \quad (\text{smooth tube})$$

$$\Delta P = 4f \frac{L}{D} \frac{\rho v^2}{2g_c}$$

$$= (4)(.006) \frac{(4.82)}{(.017)} \frac{(62.4)(2.06)^2}{2(32.17)(144)}$$

$$= .19 \text{ psi}$$

#### Shell and Tube Heat Exchanger

Use 150 1/8" tubes by 1.75" long, .082 Crimp. One pass shell side, one pass tube side.

Water (tube) side:

$$\text{Flow Area} = N_T \frac{\pi d_i^2}{4}$$

$$= (150)\pi \frac{(.099)^2}{4(144)}$$

$$= .008 \text{ ft}^2$$

$$G = \frac{W}{A} = \frac{240 \text{ lb/hr}}{.008 \text{ ft}^2}$$

$$= 30000 \frac{\text{lb}}{\text{hr-ft}^2}$$

$$D_e = \frac{.099}{12} = .00825 \text{ ft}$$



$$N_{Re} = \frac{DeG}{\mu}$$

$$= \frac{(.00825)(30000)}{3.1} = 79.8$$

$$j = N_{Nu} N_{Pr}^{-.4} = 1.9 \quad (\text{Test Data .082 Crimp})$$

$$\frac{hD}{K} = 1.9 \left( \frac{CP\mu}{K} \right)^{.4}$$

$$h_t = 1.9 \frac{K}{D} \left( \frac{CP\mu}{K} \right)^{.4}$$

$$= \frac{1.9(.332)}{(.00683)} \left( \frac{(1.0)(3.1)}{(.332)} \right)^{.4}$$

$$= 225.7 \text{ Btu/hr-ft}^2\text{-}^\circ\text{F}$$

Slurry (shell) side:

$$\text{Flow Area} = .5 \frac{\text{in}^2}{\text{in length}} \times 1.75 \text{ in (Design Data)}$$

$$= .875 \text{ in}^2$$

$$= 6.076 \times 10^{-3} \text{ ft}^2$$

$$G = \frac{W}{A} = \frac{240}{6.076 \times 10^{-3}} = 39497 \frac{\text{lb}}{\text{hr-ft}^2}$$

$$De = \frac{.125}{12} = .01042 \text{ ft}$$

$$N_{Re} = \frac{DeG}{\mu}$$

$$= \frac{(.01042)(39497)}{12.1} = 34$$

$$N_{Nu} N_{Pr}^{-.33} = 2.5 \quad (\text{Test Data})$$

$$h_s = \frac{K}{D} \left( \frac{CP\mu}{K} \right)^{.33} \quad (2.5)$$

$$= \frac{(.26)}{(.01042)} \left( \frac{(.785)(12.1)}{(.26)} \right)^{.33} \quad (2.5)$$

$$= 204.5 \frac{\text{Btu}}{\text{hr-ft}^2-\text{°F}}$$

$$\frac{1}{UA} = \frac{1}{h_t A_t} + \frac{1}{h_s A_s}$$

$$\frac{1}{UA} = \frac{1}{(225.7) \frac{\pi (.099) (1.75) (150)}{144}} + \frac{1}{(204.5) \frac{\pi (.125) (1.75) (150)}{144}}$$

$$UA = 68.3 \frac{\text{Btu}}{\text{hr-°F}}$$

Calculate water pressure drop:

$$G = \frac{240(144)(4)}{(150)(\pi)(.082)^2} = 43628 \frac{\text{lb}}{\text{hr-ft}^2}$$

$$N_{Re} = \frac{GDe}{\mu}$$

$$= \frac{43628(.082)}{12(12.1)}$$

$$= 24.6$$

$$V = \frac{G}{\rho} = \frac{43628}{62.4} = 699 \frac{\text{ft}}{\text{hr}}$$

$$V = 699/3600 = .194 \text{ FPS}$$

$$4f = \frac{64}{24.6} = 2.6 \quad (\text{Laminar flow})$$

$$\begin{aligned} \Delta P &= 4f \frac{L}{D} \frac{\rho v^2}{2g_c} \\ &= \frac{(2.6)(1.75)(62.4)(.194)^2}{(.082)(2)(32.17)(144)} \\ &= .014 \text{ psi} \end{aligned}$$

### Plate Fin Heat Exchanger

Assume minimum Nusselt number:

$$N_{Nu} = 4.5 \quad (\text{Test Data})$$

Water fin is 0.050" high, ruffled, 35 fpi, .002 thick

$$De = .00258 \text{ ft}$$

$$\begin{aligned} h_w &= 4.5 \frac{K}{De} \\ &= \frac{4.5 (.332)}{(.00258)} = 579 \frac{\text{Btu}}{\text{hr-ft}^2-\text{°F}} \end{aligned}$$

$$\frac{A_{HT}}{V} = \frac{850 \text{ ft}^2}{\text{ft}^3} \quad (650 \text{ secondary plus } 200 \text{ primary})$$

$$\begin{aligned} A_{HT} &= (850) LxWxH \\ &= \frac{(850)(3)(4)(.05)}{1728} = .295 \text{ ft}^2 \end{aligned}$$

$$\text{Fin Effectiveness} = .53$$

$$\begin{aligned} A_{HT} &= \left[ \frac{(.53)(650) + 200}{850} \right] .295 \\ &= .189 \text{ ft}^2 \end{aligned}$$

$$hA_{\text{water}} = (579)(.189) = 109 \frac{\text{Btu}}{\text{hr-}^{\circ}\text{F}}$$

Slurry fin is .050" high, ruffled, 35 fpi, .002" thick

$$h_s = 4.5 \frac{K}{De}$$

$$= \frac{(4.5)(.26)}{.00258} = 453 \frac{\text{Btu}}{\text{hr-ft}^2-^{\circ}\text{F}}$$

$$\frac{A_{HT}}{V} = 850 \frac{\text{ft}^2}{\text{ft}^3} \quad (650 \text{ secondary plus } 200 \text{ primary})$$

$$A_{HT} = 850 LxWxH$$

$$= \frac{(850)(3)(4)(2 \times .05)}{1728} = .59 \text{ ft}^2$$

$$\text{Fin effectiveness} = .4$$

$$A_{HT} = \left[ \frac{(.4)(650) + 200}{850} \right] .59 = .32 \text{ ft}^2$$

$$hA_{\text{slurry}} = (453)(.32)$$

$$= 145 \frac{\text{Btu}}{\text{hr-}^{\circ}\text{F}}$$

$$\frac{1}{UA} = \frac{1}{hA_{\text{water}}} + \frac{1}{hA_{\text{slurry}}}$$

$$= \frac{1}{109} + \frac{1}{145}$$

$$UA = 62 \frac{\text{Btu}}{\text{hr-}^{\circ}\text{F}}$$

Increase core length by .25" to 3.25".

$$UA = 62 \left( \frac{3.25}{3} \right) = 67 \frac{\text{Btu}}{\text{hr-}^{\circ}\text{F}}$$

Calculate water pressure drop:

$$A_{ff} = w \times h \times \text{Blockage factor}$$

$$= 4 \times .05 \times .56$$

$$= .112 \text{ in}^2$$

$$G = \frac{W}{A} = \frac{240 (144)}{.112} = 308,571 \frac{\text{lb}}{\text{hr-ft}^2}$$

$$V = \frac{G}{\rho} = \frac{(308,571)}{(62.4)(3600)} = 1.374 \frac{\text{ft}}{\text{sec.}}$$

$$N_{Re} = \frac{GD}{\mu}$$

$$= \frac{(308,571)(.00258)}{(3.1)} = 257$$

$$f = \frac{16}{N_{Re}} = \frac{16}{257} = .0622$$

$$\Delta P = 4f \frac{L}{D} \frac{\rho V^2}{2g_c}$$

$$= \frac{4(.0622)(3.25)}{(.00258)(12)} \frac{(62.4)(1.374)^2}{2(32.17)(144)}$$

$$= .332 \text{ psi}$$

APPENDIX B

FUSIBLE HEAT SINK THERMAL MODEL

## APPENDIX B

### CINDA Program Capabilities

In order to solve the transient solution the computer program CINDA was used. CINDA is a versatile analytical program written by Chrysler under a NASA contract. The data is input into the program in "blocks" where each block contains different kinds of information. These blocks are (1) Title, (2) Node data, (3) Conductor data, (4) Constants data, (5) Array data, (6) Execution, (7) Variables 1, (8) Variables 2, and (9) Output calls.

The Title block allows the user to input title cards into the program. In the Node data block the user places all of the numbered nodes into the program including their initial temperature and capacitance  $C(N)$  or thermal mass value. Boundary nodes are also placed in the Node data block. In the Conductance data block the conductor number,  $G(N)$ , connecting nodes and the conductance value is input. A positive conductor number indicates a non-radiation conductor. A negative conductor number indicates a radiation conductor. In the Constants data block the user inputs constants as required by the various subroutines which the user may call. The Array data block contains arrays of data used by the subroutines that the user calls for in the different blocks. For example, thermal mass or conductance may be varied with temperature. Label arrays are also kept there, which are later called upon from the output calls block to label print-out data. In the Execution block the user identifies the size of the program and calls for the required internal subroutines from the CINDA library in order to solve the problem. In the Variables 1 block the user can perform pre-solution operations. For example, for a single power dissipation, the user may call `STFSEP(61.5,Q27)`. This means that he is assigning 61.5 watts or Btu's to node 27. The Variables 2 section allows the user to perform post-solution calculations. That is, the user can extract information from the just-solved network. For example, the call `QMETER(T1,T2,G1,K1)` calculates the heat flow between nodes 1 and 2 as a function of conductance number 1 and places this calculated value into  $K1$ . As many `QMETER` calls as desired may be used. Then with an `ADD(K1,K2,K3,K4)` statement, for example, the user sums  $K1$ ,  $K2$  and  $K3$  and places the sum into  $K4$ . In the Output calls block the user may call for a printout of the problem solution. CINDA has the additional flexibility that allows the user to include his own FORTRAN statements anywhere in the last 4 operation blocks.

The fusible heat sink cooldown model is described in Figures 1-B, 2-B, and 3-B, plus Table I-B. The warmup model is described by Figures 4-B and Table II-B. Enclosures are included for sample printout for both models.

TABLE I-B

NODE DESCRIPTION - COOLDOWN MODEL

<u>Node Number</u>	<u>Description</u>
1	Liquid Around Pump
2	Liquid Around Pump
3	Liquid Below Battery
4	Liquid Around Bladder (outer)
5	Liquid Around Bladder (inner)
6	Liquid in Expansion Tube
7	Metal S/S Bottom Below Motor
8	Metal S/S Side of Motor Section
9	Metal S/S Top of Motor Section
10	Metal S/S Top of Battery Section
11	Metal S/S Outer Side of Battery Section
12	Metal S/S Inner Side of Battery Section
13	Metal S/S Tube
14	Metal S/S Around Battery
15	Battery
16	Pump/Motor
17	Metal S/S Bottom of Battery
18	Insulation Atop Motor Section
19	Insulation Around Side of Battery Section
20	Insulation Around Tube
21	Metal S/S Bottom of Battery Section
22	Liquid Around Pump
23	Liquid Around Pump
24	Liquid Around Pump
25	Liquid Around Pump
26	Liquid Below Pump
27	Liquid Below Pump
28	Liquid Below Pump
29	Insulation Atop Battery Section
30	Insulation on Bottom of Battery Section
100	Environment



TABLE II-B

NODE DESCRIPTION - WARMUP MODEL

<u>Node Number</u>	<u>Description</u>
1	Liquid Around Pump
2	Liquid Around Pump
3	Liquid Below Battery
4	Liquid Around Bladder Outer
5	Liquid Around Bladder Inner
6	Insulation Around Side of Motor Section
7	Metal S/S Bottom Below Motor
8	Metal S/S Side of Motor Section
9	Metal S/S Top of Motor Section
10	Metal S/S Top of Battery Section
11	Metal S/S Outer Side of Battery Section
12	Metal S/S Inner Side of Battery Section
13	Insulation at Bottom of Motor Section
14	Metal S/S Around Batter
15	Battery
16	Pump/Motor
17	Metal S/S Bottom of Battery
18	Insulation Atop Motor Section
19	Insulation Around Side of Battery Section
20	Fluid in the Pump
21	Metal S/S Bottom of Battery Section
22	Liquid Around Pump
23	Liquid Around Pump
24	Liquid Around Pump
25	Liquid Around Pump
26	Liquid Below Pump
27	Liquid Below Pump
28	Liquid Below Pump
29	Insulation Atop Battery Section
30	Insulation on bottom of Battery Section
31	Fluid in Outside Circulation Loop
100	Environment




FIGURE 1-B: HEAT SINK MODEL - NODE DESCRIPTION - TOP VIEW





FIGURE 2-B: FUSIBLE HEAT SINK - NODE DESCRIPTION - SIDE VIEW COOLDOWN MODEL



COOLDOWN MODEL

FIGURE 3-B: FUSIBLE HEAT SINK - NODE DESCRIPTION - EXPANSION CIRCULATION TUBE




FIGURE 4-B: FUSIBLE HEAT SINK - NODE DESCRIPTION - SIDE VIEW WARMUP MODEL

HAMILTON STANDARD

REPORT NO.

COOLDOWN MODEL

# COOLDOWN CASE

①

BCD 3THERMAL LPCS  
BCD 9 TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK  
END

BCD 3NODE DATA

CGS 1,50.,A1,5.94 \$ LIQUID AROUND PUMP  
CGS 2,50.,A1,13.96 \$ LIQUID AROUND PUMP  
CGS 3,50.,A1,9.7 \$ LIQUID BELOW BATTERY  
CGS 4,50.,A1,3.43 \$ LIQUID AROUND BLADDER  
CGS 5,50.,A1,3.43 \$ LIQUID AROUND BLADDER  
CGS 6,50.,A1,.921 \$ LIQUID IN TUBE  
7,50.,.0212 \$ METAL S/S BOTTOM BELOW MOTOR  
8,50.,.171 \$ METAL S/S SIDE MOTOR SECTION  
9,50.,.036 \$ METAL S/S TOP MOTOR SECTION  
10,50.,.059 \$ METAL S/S TOP BATTERY SECTION  
11,50.,.067 \$ METAL S/S OUTER SIDE BATTERY SECTION  
12,50.,.067 \$ METAL S/S INNER SIDE BATTERY SECTION  
13,50.,.0133 \$ METAL S/S TUBE  
14,50.,.0666 \$ METAL S/S AROUND BATTERY  
15,50.,.528 \$ BATTERY  
16,50.,.159 \$ PUMP/MOTOR  
17,50.,.0127 \$ METAL S/S BOTTOM OF BATTERY  
18,50.,.0159 \$ INSULATION ATOP MOTOR SECTION  
19,50.,.0601 \$ INSULATION SIDE OF BATTERY SECTION  
20,50.,.0236 \$ INSULATION AROUND TUBE  
21,50.,.0127 \$ METAL BOTTOM OF BATTERY SECTION  
CGS 22,50.,A1,14.99 \$ LIQUID AROUND PUMP  
CGS 23,50.,A1,11.88 \$ LIQUID AROUND PUMP  
CGS 24,50.,A1,13.01 \$ LIQUID AROUND PUMP  
CGS 25,50.,A1,21.51 \$ LIQUID AROUND PUMP  
CGS 26,50.,A1,20.8 \$ LIQUID BELOW PUMP  
CGS 27,50.,A1,20.8 \$ LIQUID BELOW PUMP  
CGS 28,50.,A1,20.8 \$ LIQUID BELOW PUMP  
29,50.,.0114 \$ INSULATION ATOP BATTERY SECTION  
30,50.,.0114 \$ INSULATION ON BOTTOM OF BATTERY SECTION  
-100,0.00,1. \$ ENVIRONMENT

NODE NUMBER, INITIAL TEMP. °F, ARRAY 1 FOR MULTIPLIER,  
THERMAL MASS  $mcp$  BTU/°F

$$mcp @ T = mcp \times \text{MULTIPLIER}$$

BOUNDARY CONDITION AT 0°F

END

RELATIVE NODE NUMBERS

ACTUAL NODE NUMBERS

1 THRU	10	1	2	3	4	5	6	7	8	9	10	PROGRAM
11 THRU	20	11	12	13	14	15	16	17	18	19	20	RENUMBERING OF NODE
21 THRU	30	21	22	23	24	25	26	27	28	29	30	NOT INPUT
31 THRU	31	100										

BCD 3CONDUCTOR DATA

REM NOTE CGS CONDUCTOR CONSTANT VALUES FOR  $K=.375 \text{ BTU-FT/HR-FT}^2\text{-F}$   
REM  $K=1.3 \text{ BTU-FT/HR-FT}^2\text{-F AT } 6.2\text{F}$   
REM  $K=.375 \text{ BTU-FT/HR-FT}^2\text{-F AT } 18.8\text{F}$

COMMENT CARDS

CGS 10,3,12,A8,.184  
CGS 11,3,17,A8,.604  
CGS 12,3,6,A8,8.25E-4  
CGS 13,3,11,A8,.184  
CGS 14,3,21,A8,.604  
CGS 15,4,11,A8,26.2  
CGS 16,4,5,A8,9.5E-3  
CGS 17,4,14,A8,.0931  
CGS 18,5,12,A8,26.2  
CGS 19,5,14,A8,.0931

CGS 21,6,13,A8,3.22  
 22,7,21,.022  
 23,7,8,.0456  
 24,8,9,.0552  
 25,8,13,2.8E-4  
 26,9,18,.0697  
 27,9,16,2.35E-3  
 28,9,10,.0763  
 29,10,11,.0285  
 30,10,14,.0533  
 31,10,12,.0285  
 32,11,19,.467  
 33,11,12,.994  
 34,11,13,1.4E-4  
 35,11,21,.0155  
 36,13,12,1.4E-4  
 37,13,20,.0858  
 38,13,16,2.81E-4  
 39,14,17,.0533  
 40,14,15,109.1  
 41,21,12,.0155

\$ CONDUCTANCE THRU PTFE PLASTIC

CONDUCTOR NUMBER, NODE #, NODE #, ARRAY B FOR MULTIPLIER,  
 CONDUCTANCE  $\xi$  BTU/HR- $^{\circ}$ F  
 $\xi @ T = \xi \times$  MULTIPLIER

REM CONDUCTANCES FOR CONVECTION AT IG

42,100,7,.435 \$ HA\*3  
 43,100,30,.0872  
 44,100,8,3.522 \$ HA\*3  
 45,100,19,.515  
 46,100,29,.0872  
 47,100,18,.145  
 48,100,20,.1764

REM END CONDUCTANCES FOR IG EXTERNAL CONVECTION

CGS 49,1,2,A8,.035  
 CGS 50,1,24,A8,.014  
 CGS 51,1,25,A8,.014  
 CGS 52,1,9,A8,.0151  
 CGS 53,1,8,A8,1.467  
 CGS 54,1,26,A8,.0122  
 CGS 55,1,16,A9,.0899 \$ CONDUCTANCE FLUID AROUND PUMP TO PUMP  
 CGS 56,2,22,A8,.11  
 CGS 57,2,16,A10,.0539 \$ CONDUCTANCE FLUID AROUND PUMP TO PUMP  
 CGS 58,2,12,A8,.428  
 CGS 59,2,26,A8,.0288  
 CGS 60,2,9,A8,.0355  
 CGS 61,2,8,A8,.24  
 CGS 62,22,23,A8,.5  
 CGS 63,22,24,A8,.064  
 CGS 64,22,25,A8,.0309  
 CGS 65,22,12,A8,.425  
 CGS 66,22,16,A11,.095 \$ CONDUCTANCE FLUID AROUND PUMP TO PUMP  
 CGS 67,22,9,A8,.0382  
 CGS 68,23,12,A8,.1066  
 CGS 69,23,26,A8,.0245  
 CGS 70,23,25,A8,.067  
 CGS 71,23,8,A8,1.6  
 CGS 72,23,9,A9,.0302  
 CGS 73,24,16,A12,.1163 \$ CONDUCTANCE FLUID AROUND PUMP TO PUMP  
 CGS 74,24,25,A8,.6  
 CGS 75,24,9,A8,.0331  
 CGS 76,24,26,A8,.0268  
 CGS 77,25,8,A8,1.57  
 CGS 78,25,26,A9,.0443



REPRODUCIBILITY OF THE  
ORIGINAL PAGE IS POOR

CGS 80,26,27,A8,.466  
CGS 81,26,16,A8,.0548  
CGS 82,26,12,A8,.0325  
CGS 83,26,8,A8,.37  
CGS 84,27,28,A8,.466  
CGS 85,27,8,A8,.37  
CGS 86,27,12,A8,.0325  
CGS 87,28,7,A8,.932  
CGS 88,28,8,A8,.37  
CGS 89,28,12,A8,.0325

90,18,29,7.41E-4  
91,29,19,.01645  
92,19,29,8.75E-4  
93,30,21,.0419  
94,30,19,8.75E-4

REM RADIATION CONDUCTORS

-100,4,14,2.05E-10  
-101,5,14,2.05E-10  
-102,100,7,2.49E-10  
-103,100,30,.0747E-10  
-104,100,8,20.1E-10  
-105,100,19,.441E-10  
-106,100,29,.0747E-10  
-107,100,18,.124E-10  
-108,100,20,.151E-10

\$ INSULATION E=.05

\$ INSULATION E=.05

\$ INSULATION E=.05

\$ INSULATION E=.05

\$ INSULATION E=.05

END

RADIATION CONDUCTORS

RELATIVE CONDUCTOR NUMBERS

ACTUAL CONDUCTOR NUMBERS

1	THRU	10	10	11	12	13	14	15	16	17	18	19
11	THRU	20	20	21	22	23	24	25	26	27	28	29
21	THRU	30	30	31	32	33	34	35	36	37	38	39
31	THRU	40	40	41	42	43	44	45	46	47	48	49
41	THRU	50	50	51	52	53	54	55	56	57	58	59
51	THRU	60	60	61	62	63	64	65	66	67	68	69
61	THRU	70	70	71	72	73	74	75	76	77	78	79
71	THRU	80	80	81	82	83	84	85	86	87	88	89
81	THRU	90	90	91	92	93	94	100	101	102	103	104
91	THRU	94	105	106	107	108						

PROGRAM  
RENUMBERING  
OF CONDUCTORS  
NOT INPUT

BCD 3CONSTANTS DATA

TIMEND,96.,OUTPUT,1.0

DTIME1,.1

NLOOP,3000

DRLXCA,.05,ARLXCA,.05

1,0.,2,0.,3,0.,4,0.,5,0.,6,0.,7,0.,8,0.,9,0.

10,0.,11,0.,12,0.,13,0.,14,0.,15,0.,16,0.,17,0.,18,0.

← RUNNING TIME FOR PROBLEM HOURS, OUTPUT PRINTOUT INTERVAL HOURS

← INPUT REQ'D FOR TRANSIENT ROUTINE CNFWBK (EXECUTION BLOCK)

← INITIALIZING CONSTANTS USED IN VARIABLES 2

END

BCD 3ARRAY DATA

1,-50.,.0457,6.19,.0457,6.20,1.0,18.79,1.0,18.8,.0457

100.,.0457,END

-2,ORRATE,ORTOT,QCRATE,QCTOT,END

-4,C1,C2,C22,C23,END

-5,C24,C25,C26,C27,END

-6,C28,C3,C4,C5,END

-7,C6,G53,G62,END

← ARRAY NUMBER (TEMP, MULTIPLIER, TEMP MULTIPLIER)

← LABEL ARRAY CALLED FROM OUTPUT CALLS

REM NOTE CHANGE IN ARRAY DATA 9 THRU 12

8,-50.,3.47,6.20,3.47,18.80,1.0,100.,1.0,END

9,-50.,1.36,6.20,1.36,18.80,1.0,100.,1.0,END

10,-50.,2.03,6.20,2.03,18.80,1.0,100.,1.0,END

11,-50.,1.78,6.20,1.78,18.80,1.0,100.,1.0,END

END  
BCD 3EXECUTION  
DIMENSION X(200)  
NDIM=200  
NTH=0

F  
F  
F

INDICATES SIZE OF PROGRAM

CSGDMP  
CNFWRK

CALL FOR ORDERED NODE-CONDUCTANCE PRINT  
TRANSIENT ROUTINE

END  
BCD 3VARIABLES 1

VARCSM(T	1,C	1,A1,5.94)
VARCSM(T	2,C	2,A1,13.96)
VARCSM(T	3,C	3,A1,9.7)
VARCSM(T	4,C	4,A1,3.43)
VARCSM(T	5,C	5,A1,3.43)
VARCSM(T	6,C	6,A1,.921)
VARCSM(T	22,C	22,A1,14.99)
VARCSM(T	23,C	23,A1,11.88)
VARCSM(T	24,C	24,A1,13.01)
VARCSM(T	25,C	25,A1,21.51)
VARCSM(T	26,C	26,A1,20.8)
VARCSM(T	27,C	27,A1,20.8)
VARCSM(T	28,C	28,A1,20.8)
VARGSM(G	10,T	3,T 12,A8,.184)
VARGSM(G	11,T	3,T 17,A8,.604)
VARGSM(G	12,T	3,T 6,A8,8.25E-4)
VARGSM(G	13,T	3,T 11,A8,.184)
VARGSM(G	14,T	3,T 21,A8,.604)
VARGSM(G	15,T	4,T 11,A8,26.2)
VARGSM(G	16,T	4,T 5,A8,9.5E-3)
VARGSM(G	17,T	4,T 14,A8,.0931)
VARGSM(G	18,T	5,T 12,A8,26.2)
VARGSM(G	19,T	5,T 14,A8,.0931)
VARGSM(G	20,T	6,T 16,A8,8.25E-4)
VARGSM(G	21,T	6,T 13,A8,3.22)
VARGSM(G	49,T	1,T 2,A8,.035)
VARGSM(G	50,T	1,T 24,A8,.014)
VARGSM(G	51,T	1,T 25,A8,.014)
VARGSM(G	52,T	1,T 9,A8,.0151)
VARGSM(G	53,T	1,T 8,A8,1.467)
VARGSM(G	54,T	1,T 26,A8,.0122)
VARGSM(G	55,T	1,T 16,A9,.0899)
VARGSM(G	56,T	2,T 22,A8,.11)
VARGSM(G	57,T	7,T 16,A10,.0539)
VARGSM(G	58,T	2,T 12,A8,.428)
VARGSM(G	59,T	2,T 26,A8,.0288)
VARGSM(G	60,T	2,T 9,A8,.0355)
VARGSM(G	61,T	2,T 8,A8,.24)
VARGSM(G	62,T	22,T 23,A8,.5)
VARGSM(G	63,T	22,T 24,A8,.064)
VARGSM(G	64,T	22,T 26,A8,.0309)
VARGSM(G	65,T	22,T 12,A8,.475)
VARGSM(G	66,T	22,T 16,A11,.095)
VARGSM(G	67,T	22,T 9,A8,.0382)
VARGSM(G	68,T	23,T 12,A8,.1066)
VARGSM(G	69,T	23,T 26,A8,.0245)
VARGSM(G	70,T	23,T 25,A8,.067)
VARGSM(G	71,T	23,T 8,A8,1.6)
VARGSM(G	72,T	23,T 9,A8,.0302)
VARGSM(G	73,T	24,T 16,A12,.1163)
VARGSM(G	74,T	24,T 25,A8,.6)

DONE BY PROGRAM - NOT INPUT

VARGSMIG 76,T 24,T 26,A8,.026P)  
 VARGSMIG 77,T 25,T 8,A8,1.67)  
 VARGSMIG 78,T 25,T 26,A8,.0443)  
 VARGSMIG 79,T 25,T 9,A8,.0547)  
 VARGSMIG 80,T 26,T 27,A8,.466)  
 VARGSMIG 81,T 26,T 16,A8,.0548)  
 VARGSMIG 82,T 26,T 12,A8,.0325)  
 VARGSMIG 83,T 26,T 8,A8,.371  
 VARGSMIG 84,T 27,T 28,A8,.466)  
 VARGSMIG 85,T 27,T 8,A8,.371  
 VARGSMIG 86,T 27,T 17,A8,.0325)  
 VARGSMIG 87,T 28,T 7,A8,.932)  
 VARGSMIG 88,T 28,T 8,A8,.371  
 VARGSMIG 89,T 28,T 12,A9,.0325)

ENDV1  
 STFSEP(3.41,Q13) \$ 1 WATT AROUND TUBE  
 STFSEP(.201,G53) \$ AIR GAP .05 IN NODE 1 TO NODE 8

PLACES 3.41 BTU/HR IN NODE 13

PLACES .201 BTU/HR-°F IN CONDUCTOR 53

END.  
 BCD 3VARIABLES 2

QMETER(T7,T100,G42,K10)  
 QMETER(T30,T100,G43,K11)  
 QMETER(T8,T100,G44,K12)  
 QMETER(T19,T100,G45,K13)  
 QMETER(T29,T100,G46,K14)  
 QMETER(T18,T100,G47,K15)  
 QMETER(T20,T100,G48,K16)

PLACES  $Q = q(42) \times (T(7) - T(100))$  INTO CONSTANT LOCATION K10

ADD(K10,K11,K12,K13,K14,K15,K16,K17)

ADDS K'S AND PUTS SUM IN K17  
 SUMS HEAT FOR EACH TIME STEP

QINTEG(K17,DTIMEU,K18) \$ INTEGRATE CONVECTION HEAT FLOW

PLACES  $Q = q(03) \times (T(30) - T(100))$  INTO K2

RDTNQS(T100,T7,G102,K1)  
 RDTNQS(T100,T30,G103,K2)  
 RDTNQS(T100,T8,G104,K3)  
 RDTNQS(T100,T19,G105,K4)  
 RDTNQS(T100,T29,G106,K5)  
 RDTNQS(T100,T18,G107,K6)  
 RDTNQS(T100,T20,G108,K7)

ADD(K1,K2,K3,K4,K5,K6,K7,K8)

QINTEG(K8,DTIMEU,K9) \$ INTEGRATE RADIATION HEAT FLOW

END

BCD 3OUTPUT CALLS

PRINTS ALL NODE TEMPERATURES

PRNTMP

PRINTL(A2,K8,K9,K17,K18)

PRINTS LABELS FROM ARRAY 2 FOR CONSTANTS IN SEQUENCE

PRINTL(A4,C1,C2,C22,C23)

PRINTL(A5,C24,C25,C26,C27)

PRINTL(A6,C28,C3,C4,C5)

PRINTL(A7,C6,G53,G62)

END

## TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

\* \* \* \*  
 TIME 0.0 DTIMEU 0.0 CSGMIN( 0) 0.0 DTMPCC( 0) 0.0 ARLXCC( 0) 0.0

1 THRU 5	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
6 THRU 10	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
11 THRU 15	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
16 THRU 20	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
21 THRU 25	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
26 THRU 30	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
31 THRU 31	0.0				

QRRR 0.0	QRTD 0.0	QCRA 0.0	QCTD 0.0
C1 0.27146E 00 C2	0.63797E 00 C22	0.68504E 00 C23	0.54292E 00
C24 0.59456E 00 C25	0.98301E 00 C26	0.95056E 00 C27	0.95056E 00
C28 0.95056E 00 C3	0.44329E 00 C4	0.15675E 00 C5	0.15675E 00

C6 0.42090E-01 G53 0.20100E 00 G62 0.50000F 00

A 30 NODE PROBLEM USING 1PCS

NODE 14 HAS THE CSGMIN OF 6.07607E-04, NODE 26 HAS THE CSGMAX OF 8.71434E-01

NODE C-VALUE CSG-VALUE COND TYPE G-VALUE TO NODE TYPE

1 2.715E-01 7.121E-01

WHAT FOLLOWS IS THE RESULT OF  
 CSGMP CALL IN EXECUTION BLOCK  
 CONDUCTANCE  $\bar{C}$  IN BTU/HR- $\bar{C}$ F

$\frac{C}{BTU/HR}$	$\frac{C}{\Sigma \bar{C}}$	HOURS	40 LIN 3.500E-02	2 DIFF
			41 LIN 1.400E-02	24 DIFF
			42 LIN 1.400E-02	25 DIFF
			43 LIN 1.510E-02	9 DIFF
			44 LIN 2.010E-01	8 DIFF
			45 LIN 1.220E-02	26 DIFF
			46 LIN 8.990E-02	16 DIFF

RELATIVE CONDUCTOR NUMBER →

2 6.380E-01 6.851E-01

40 LIN 3.500E-02	1 DIFF
47 LIN 1.100E-01	22 DIFF
48 LIN 5.390E-02	16 DIFF
49 LIN 4.280E-01	12 DIFF
50 LIN 2.880E-02	26 DIFF
51 LIN 3.550E-02	9 DIFF
52 LIN 2.400E-01	8 DIFF

3 4.433E-01 2.811E-01

1 LIN 1.840E-01	12 DIFF
2 LIN 6.040E-01	17 DIFF
3 LIN 8.250E-04	6 DIFF
4 LIN 1.840E-01	11 DIFF
5 LIN 6.040E-01	21 DIFF

4 1.568E-01 5.935E-03

6 LIN 2.620E 01	11 DIFF
7 LIN 9.500E-03	5 DIFF
8 LIN 9.310E-02	14 DIFF
86 RAD 2.050E-10	14 DIFF

5 1.568E-01 5.935E-03

7 LIN 9.500E-03	4 DIFF
9 LIN 2.620E 01	12 DIFF
10 LIN 9.310E-02	14 DIFF

REPRODUCIBILITY OF THE  
 ORIGINAL PAGE IS

6 4.209E-02 1.306E-02

3 LIN 8.250E-04 3 DIFF

B-15

TRW SYSTEMS IMPROVED NUMERICAL DIFFERENCING ANALYZER

SINDA

IBM-360/75 VERSION, PHILLIPS PETROLEUM CO. PAGE 2

TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

7 2.120E-02 1.369E-02

11 LIN 8.250E-04 16 DIFF  
12 LIN 2.220E 00 13 DIFF

8 1.710E-01 1.826E-02

13 LIN 2.200E-02 21 DIFF  
14 LIN 4.560E-02 8 DIFF  
33 LIN 4.350E-01 31 BOUN  
78 LIN 9.320E-01 28 DIFF  
88 RAD 2.490E-10 31 BOUN

9 3.600E-02 9.721E-02

14 LIN 4.560E-02 7 DIFF  
15 LIN 5.520E-02 9 DIFF  
16 LIN 2.800E-04 13 DIFF  
35 LIN 3.522E 00 31 BOUN  
44 LIN 2.010E-01 1 DIFF  
52 LIN 2.400E-01 2 DIFF  
62 LIN 1.600E 00 23 DIFF  
68 LIN 1.670E 00 25 DIFF  
74 LIN 3.700E-01 26 DIFF  
76 LIN 3.700E-01 27 DIFF  
79 LIN 3.700E-01 28 DIFF  
90 RAD 2.010E-09 31 BOUN

10 5.900E-02 3.619E-01

15 LIN 5.520E-02 8 DIFF  
17 LIN 6.970E-02 18 DIFF  
18 LIN 2.350E-03 16 DIFF  
19 LIN 3.630E-02 10 DIFF  
43 LIN 1.510E-02 1 DIFF  
51 LIN 3.550E-02 2 DIFF  
58 LIN 3.820E-02 22 DIFF  
63 LIN 3.020E-02 23 DIFF  
66 LIN 3.310E-02 24 DIFF  
70 LIN 5.470E-02 25 DIFF

11 6.700E-02 2.402E-03

19 LIN 2.630E-02 9 DIFF  
20 LIN 2.850E-02 11 DIFF  
21 LIN 5.330E-02 14 DIFF  
22 LIN 2.850E-02 12 DIFF  
82 LIN 1.645E-02 29 DIFF

12 6.700E-02 2.353E-03

4 LIN 1.840E-01 3 DIFF  
6 LIN 2.620E 01 4 DIFF  
20 LIN 2.850E-02 10 DIFF  
23 LIN 4.670E-01 19 DIFF  
24 LIN 9.940E-01 12 DIFF  
25 LIN 1.400E-04 13 DIFF  
26 LIN 1.550E-02 21 DIFF

1 LIN 1.840E-01 3 DIFF  
9 LIN 2.620E 01 5 DIFF

P-16

TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

	22	LIN 2.950E-02	10 DIFF
	24	LIN 9.940E-01	11 DIFF
	27	LIN 1.400E-04	13 DIFF
	32	LIN 1.550E-02	21 DIFF
	49	LIN 4.280E-01	2 DIFF
	56	LIN 4.250E-01	22 DIFF
	59	LIN 1.066E-01	23 DIFF
	73	LIN 3.250E-02	26 DIFF
	77	LIN 3.250E-02	27 DIFF
	80	LIN 3.250E-02	28 DIFF
13	1.330E-02	4.022E-03	
	12	LIN 3.220E 00	6 DIFF
	16	LIN 2.800E-04	8 DIFF
	25	LIN 1.400E-04	11 DIFF
	27	LIN 1.400E-04	12 DIFF
	28	LIN 8.580E-02	20 DIFF
	29	LIN 2.810E-04	16 DIFF
14	6.660E-02	6.076E-04	
	8	LIN 9.310E-02	4 DIFF
	10	LIN 9.310E-02	5 DIFF
	21	LIN 5.330E-02	10 DIFF
	30	LIN 5.330E-02	17 DIFF
	31	LIN 1.091E 02	15 DIFF
	86	RAD 2.050E-10	4 DIFF
	87	RAD 2.050E-10	5 DIFF
15	5.280E-01	4.840E-03	
16	1.590E-01	3.847E-01	
	31	LIN 1.091E 02	14 DIFF
	11	LIN 8.250E-04	6 DIFF
	18	LIN 2.350E-03	9 DIFF
	29	LIN 2.810E-04	13 DIFF
	46	LIN 8.990E-02	1 DIFF
	48	LIN 5.390E-02	2 DIFF
	57	LIN 9.500E-02	22 DIFF
	64	LIN 1.163E-01	24 DIFF
	72	LIN 5.480E-02	26 DIFF
17	1.270E-02	1.932E-02	
	2	LIN 6.040E-01	3 DIFF
	30	LIN 5.330E-02	14 DIFF
18	1.590E-02	7.191E-02	
	17	LIN 6.970E-02	9 DIFF
	38	LIN 1.450E-01	31 BCUN
	81	LIN 7.410E-04	29 DIFF
	93	RAD 1.240E-11	31 BCUN
19	6.010E-02	5.986E-02	
	23	LIN 4.670E-01	11 DIFF
	36	LIN 5.150E-01	31 BCUN
	83	LIN 8.750E-04	29 DIFF
	85	LIN 8.750E-04	30 DIFF

B-17

## TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

20 2.360E-02 8.770E-02 91 RAD 4.410E-11 31 BOUN

28 LIN 8.580E-02 13 DIFF  
39 LIN 1.764E-01 31 BOUN  
94 RAD 1.510E-11 31 BOUN

21 1.270E-02 1.817E-02

5 LIN 6.040E-01 3 DIFF  
13 LIN 2.200E-02 7 DIFF  
26 LIN 1.550E-02 11 DIFF  
32 LIN 1.550E-02 12 DIFF  
84 LIN 4.190E-02 30 DIFF

22 6.850E-01 5.424E-01

47 LIN 1.100E-01 2 DIFF  
53 LIN 5.000E-01 23 DIFF  
54 LIN 6.400E-02 24 DIFF  
55 LIN 3.090E-02 26 DIFF  
56 LIN 4.250E-01 12 DIFF  
57 LIN 9.500E-02 16 DIFF  
58 LIN 3.820E-02 9 DIFF

23 5.429E-01 2.332E-01

53 LIN 5.000E-01 22 DIFF  
59 LIN 1.066E-01 12 DIFF  
60 LIN 2.450E-02 26 DIFF  
61 LIN 6.700E-02 25 DIFF  
62 LIN 1.610E-00 8 DIFF  
63 LIN 3.020E-02 9 DIFF

24 5.946E-01 6.960E-01

41 LIN 1.400E-02 1 DIFF  
54 LIN 6.400E-02 22 DIFF  
64 LIN 1.163E-01 16 DIFF  
65 LIN 6.000E-01 25 DIFF  
66 LIN 3.310E-02 9 DIFF  
67 LIN 2.680E-02 26 DIFF

25 9.830E-01 4.012E-01

42 LIN 1.400E-02 1 DIFF  
61 LIN 6.700E-02 23 DIFF  
65 LIN 6.000E-01 24 DIFF  
68 LIN 1.670E-00 8 DIFF  
69 LIN 4.430E-02 26 DIFF  
70 LIN 5.470E-02 9 DIFF

26 9.506E-01 8.714E-01

45 LIN 1.220E-02 1 DIFF  
50 LIN 2.880E-02 2 DIFF  
55 LIN 3.090E-02 22 DIFF  
60 LIN 2.450E-02 23 DIFF  
67 LIN 2.680E-02 24 DIFF  
69 LIN 4.430E-02 25 DIFF  
71 LIN 4.660E-01 27 DIFF  
72 LIN 5.480E-02 16 DIFF



## TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

27 9.506E-01 7.123E-01  
 28 9.506E-01 5.279E-01  
 29 1.140E-02 1.049E-01  
 30 1.140E-02 8.546E-02

73 LIN 3.250E-02 12 DIFF  
 74 LIN 3.700E-01 8 DIFF  
 71 LIN 4.660E-01 26 DIFF  
 75 LIN 4.660E-01 28 DIFF  
 76 LIN 3.700E-01 8 DIFF  
 77 LIN 3.250E-02 12 DIFF  
 75 LIN 4.660E-01 27 DIFF  
 78 LIN 9.320E-01 7 DIFF  
 79 LIN 3.700E-01 8 DIFF  
 80 LIN 3.250E-02 12 DIFF  
 37 LIN 8.720E-02 31 BOUN  
 81 LIN 7.410E-04 18 DIFF  
 82 LIN 1.645E-02 10 DIFF  
 83 LIN 8.750E-04 19 DIFF  
 92 RAD 7.470E-12 31 BOUN  
 34 LIN 8.720E-02 31 BOUN  
 84 LIN 4.190E-02 21 DIFF  
 85 LIN 8.750E-04 19 DIFF  
 89 RAD 7.470E-12 31 BOUN

B-19

\* \* \* \*  
TIME 0.0

DTIMEU 0.0

CSGMIN( 0) 0.0

DTMPCC( 0) 0.0

ARLXCC( 0) 0.0

1 THRU	5	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
6 THRU	10	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
11 THRU	15	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
16 THRU	20	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
21 THRU	25	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
26 THRU	30	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01	5.000000E 01
31 THRU	31	0.0				

QRRA 0.0 QRTD 0.0 QCRA 0.0 QCTD 0.0

C1 0.27146E 00 C2 0.63797E 00 C22 0.68504E 00 C23 0.54292E 00  
 C24 0.59456E 00 C25 0.98301E 00 C26 0.95056E 00 C27 0.95056E 00  
 C28 0.95056E 00 C3 0.44329E 00 C4 0.15675E 00 C5 0.15675E 00  
 C6 0.42090E-01 G53 0.20100E 00 G62 0.50000E 00

\* \* \* \*  
 TIME 1.00000E 00 DTIMEU 5.00002E-02 CSGMIN( 14) 6.07658E-04 DTMPCC( 28) 6.68213E-01 ARLXCC( 5) 1.46484E-03

1 THRU	5	3.557642E 01	3.989941E 01	4.325879E 01	3.559595E 01	3.901025E 01
6 THRU	10	5.668652E 01	2.015356E 01	1.593970E 01	2.822119E 01	3.822583E 01
11 THRU	15	3.547729E 01	3.890015E 01	5.686987E 01	4.568579E 01	4.571655E 01
16 THRU	20	4.322974E 01	4.361084E 01	9.168701E 00	1.677246E 01	1.810571E 01
21 THRU	25	4.059937E 01	3.999756E 01	2.518628E 01	4.032666E 01	2.791846E 01

TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

6 THRU 10	5.649922E 01	1.181787E 01	1.020386E 01	1.360669E 01	1.467993E 01
11 THRU 15	1.564355E 01	1.701563E 01	5.671924E 01	1.696167E 01	1.696729E 01
16 THRU 20	1.769189E 01	1.816113E 01	4.316650E 00	7.315186E 00	1.812866E 01
21 THRU 25	1.735522E 01	1.758765E 01	1.277612E 01	1.772168E 01	1.399927E 01
26 THRU 30	1.725806E 01	1.714331E 01	1.511572E 01	2.325928E 00	5.520752E 00
31 THRU 31	0.0				

QARR	0.97315F 01 QRTN	0.10694E 03 QCRA	0.49354F 02 QCTO	0.54208E 03
C1	0.59400E 01 C2	0.13960F 02 C22	0.14990E 02 C23	0.11880E 02
C24	0.13010E 02 C25	0.21510E 02 C26	0.20800E 02 C27	0.20800F 02
C28	0.20800E 02 C3	0.97000E 01 C4	0.34300E 01 C5	0.34300F 01
C6	0.42090E-01 G53	0.20100E 00 G62	0.85286F 00	

\* \* \* \*  
TIME 1.00000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.07253E-04 DTMPCC( 14) 3.41797E-02 ARLXCC( 14) 3.90625E-03

NODES

TEMPERATURES °F

1 THRU 5	1.708105E 01	1.723267E 01	1.806055E 01	1.526465E 01	1.665259E 01
6 THRU 10	5.668555E 01	1.157373E 01	9.987549E 00	1.333472E 01	1.427466E 01
11 THRU 15	1.522778E 01	1.661890E 01	5.670581E 01	1.645996E 01	1.646509E 01
16 THRU 20	1.739771E 01	1.795068E 01	4.230469E 00	7.119873E 00	1.812427E 01
21 THRU 25	1.718408E 01	1.726416E 01	1.239551E 01	1.741504E 01	1.350879E 01
26 THRU 30	1.698169E 01	1.682349E 01	1.470166E 01	2.260742E 00	5.465576E 00
31 THRU 31	0.0				

TOTAL RADIATION LOST, BTU

TOTAL CONVECTION LOST, BTU

QARR	0.95210E 01 QRTN	0.11655E 03 QCRA	0.48362E 02 QCTO	0.59088E 03
C1	0.59400E 01 C2	0.13960E 02 C22	0.14990E 02 C23	0.11880E 02
C24	0.13010E 02 C25	0.21510E 02 C26	0.20800E 02 C27	0.20800E 02
C28	0.20800E 02 C3	0.97000E 01 C4	0.34300E 01 C5	0.34300E 01
C6	0.42090E-01 G53	0.20100E 00 G62	0.88748E 00	

THERMAL MASSES C(N), BTU/°F

CONDUCTANCES G(N), BTU/HR-°F

\* \* \* \*  
TIME 1.10000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.07166E-04 DTMPCC( 15) 2.31934E-02 ARLXCC( 14) 3.41797E-03

1 THRU 5	1.691274E 01	1.693042E 01	1.785229E 01	1.489502E 01	1.528271E 01
6 THRU 10	5.668213E 01	1.133105E 01	9.785400E 00	1.307397E 01	1.392383E 01
11 THRU 15	1.486304E 01	1.625391E 01	5.670190E 01	1.602246E 01	1.602319E 01
16 THRU 20	1.708960E 01	1.772998E 01	4.146484E 00	6.948486E 00	1.812329E 01
21 THRU 25	1.700049E 01	1.692358E 01	1.206616E 01	1.708301E 01	1.306616E 01
26 THRU 30	1.669727E 01	1.649585E 01	1.430176E 01	2.205078E 00	5.406982E 00
31 THRU 31	0.0				

QARR	0.93233E 01 QRTN	0.12596E 03 QCRA	0.47434F 02 QCTO	0.63873E 03
C1	0.59400E 01 C2	0.13960E 02 C22	0.14990E 02 C23	0.11880E 02

C28 0.20800E 02 C3 0.97000E 01 C4 0.34300E 01 C5 0.34300E 01  
 C6 0.42090E-01 G53 0.20100E 00 G62 0.11482E 01

\* \* \* \*  
 TIME 2.00000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.06610E-04 DTMPCC( 15) 1.85547E-02 ARLXCC( 14) 5.37109E-03

1	THRU	5	1.440356E 01	1.414087E 01	1.541255E 01	1.258203E 01	1.362622E 01
6	THRU	10	5.657788E 01	9.363037E 00	8.307129E 00	1.101025E 01	1.166333E 01
11	THRU	15	1.256567E 01	1.361035E 01	5.659937E 01	1.338525E 01	1.338501E 01
16	THRU	20	1.414111E 01	1.550122E 01	3.492920E 00	5.872559E 00	1.809033E 01
21	THRU	25	1.501245E 01	1.382544E 01	1.000391E 01	1.370874E 01	1.038599E 01
26	THRU	30	1.398950E 01	1.349341E 01	1.135645E 01	1.845703E 00	4.775391E 00
31	THRU	31	0.0				

QRRR 0.78672E 01 QRTD 0.20293E 03 QCRA 0.40630E 02 QCTD 0.10332E 04  
 C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.11880E 02  
 C24 0.13010E 02 C25 0.21510E 02 C26 0.20800E 02 C27 0.20800E 02  
 C28 0.20800E 02 C3 0.97000E 01 C4 0.34300E 01 C5 0.34300E 01  
 C6 0.42090E-01 G53 0.20100E 00 G62 0.11737E 01

\* \* \* \*  
 TIME 2.10000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.06556E-04 DTMPCC( 24) 1.80664E-02 ARLXCC( 14) 1.12305E-02

1	THRU	5	1.414087E 01	1.383716E 01	1.534497E 01	1.236426E 01	1.335962E 01
---	------	---	--------------	--------------	--------------	--------------	--------------

## TRANSIENT WATER/KHF2/ETHANDL FUSIBLE HEAT SINK

6	THRU	10	5.647607E 01	7.764160E 00	7.045410E 00	9.99941E 00	9.783203E 00
11	THRU	15	1.065381E 01	1.130542E 01	5.649878E 01	1.73291E 01	1.123096E 01
16	THRU	20	1.147461E 01	1.309009E 01	2.914551E 00	4.980225E 00	1.805786E 01
21	THRU	25	1.275903E 01	1.120630E 01	8.399902E 00	1.080566E 01	8.589355E 00
26	THRU	30	1.134106E 01	1.083154E 01	9.209717E 00	1.548828E 00	4.060059E 00
31	THRU	31	0.0				

QRR	A	0.66437E 01	QRTD	0.26808E 03	QCRA	0.34853E 02	QCTD	0.13722E 04
C1		0.59400E 01	C2	0.13960E 02	C22	0.14990E 02	C23	0.11880E 02
C24		0.13010E 02	C25	0.21510E 02	C26	0.20800E 02	C27	0.20800E 02
C28		0.20800E 02	C3	0.97000E 01	C4	0.34300E 01	C5	0.34300E 01
C6		0.42090E-01	G53	0.20100E 00	G62	0.13808E 01		

\* \* \* \*  
TIME 3.00000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.06088E-04 DTMPCC( 14) 1.80664E-02 ARLXCC( 14) 1.95313E-03

1	THRU	5	1.185083E 01	1.129492E 01	1.289380E 01	1.045923E 01	1.107397E 01
6	THRU	10	5.646460E 01	7.603027E 00	6.910400E 00	8.928779E 00	9.582764E 00
11	THRU	15	1.044653E 01	1.106274E 01	5.648730E 01	1.099780E 01	1.100073E 01
16	THRU	20	1.120679E 01	1.282178E 01	2.854004E 00	4.883301E 00	1.805444E 01
21	THRU	25	1.250439E 01	1.094653E 01	8.231934E 00	1.052856E 01	8.406982E 00
26	THRU	30	1.106738E 01	1.056567E 01	9.001465E 00	1.517334E 00	3.979248E 00
31	THRU	31	0.0				

QRR	A	0.65144E 01	QRTD	0.27465E 03	QCRA	0.34239E 02	QCTD	0.14067E 04
C1		0.59400E 01	C2	0.13960E 02	C22	0.14990E 02	C23	0.11880E 02
C24		0.13010E 02	C25	0.21510E 02	C26	0.20800E 02	C27	0.20800E 02
C28		0.20800E 02	C3	0.97000E 01	C4	0.34300E 01	C5	0.34300E 01
C6		0.42090E-01	G53	0.20100E 00	G62	0.14018E 01		

\* \* \* \*  
TIME 3.10000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.06040E-04 DTMPCC( 15) 1.53809E-02 ARLXCC( 14) 3.90625E-03

1	THRU	5	1.160718E 01	1.103564E 01	1.262329E 01	1.025342E 01	1.083545E 01
6	THRU	10	5.645313E 01	7.445068E 00	6.777100E 00	8.811768E 00	9.389404E 00
11	THRU	15	1.024072E 01	1.082422E 01	5.647607E 01	1.078711E 01	1.078833E 01
16	THRU	20	1.094458E 01	1.255518E 01	2.795410E 00	4.787109E 00	1.805103E 01
21	THRU	25	1.225049E 01	1.069189E 01	8.066406E 00	1.025952E 01	8.227539E 00
26	THRU	30	1.079834E 01	1.030664E 01	8.798340E 00	1.486328E 00	3.897949E 00
31	THRU	31	0.0				

QRR	A	0.63869E 01	QRTD	0.28109E 03	QCRA	0.33632E 02	QCTD	0.14406E 04
C1		0.59400E 01	C2	0.13960E 02	C22	0.14990E 02	C23	0.11880E 02

REPRODUCED BY THE  
ORIGINAL PAGE IS POOR

C28 0.20800E 02 C3 0.97000E 01 C4 0.34300F 01 C5 0.34300E 01  
 C6 0.42090F-01 G53 0.20100E 00 G62 0.15751E 01

\* \* \* \*  
 TIME 4.00000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.05606E-04 DTMPCC( 14) 1.66016F-02 ARLXCC( 14) 1.95313E-03

1 THRU 5	9.546631E 00	8.908447E 00	1.030005E 01	8.429688F 00	8.807129E 00
6 THRU 10	5.636816E 01	6.138184E 00	5.634766E 00	7.238525E 00	7.686279E 00
11 THRU 15	8.420898E 00	8.799072E 00	5.639258F 01	8.814697E 00	8.816895E 00
16 THRU 20	8.823730E 00	1.025415E 01	2.295654E 00	3.937012E 00	1.802393E 01
21 THRU 25	1.004517E 01	8.635010E 00	6.653564E 00	9.183838E 00	6.744141E 00
26 THRU 30	8.618164E 00	8.239014E 00	7.157471E 00	1.216553E 00	3.196777E 00
31 THRU 31	0.0				

QRRA 0.53033E 01 QRTD 0.33354E 03 QCRA 0.28440E 02 QCTD 0.17193E 04  
 C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.11880E 02  
 C24 0.13010E 02 C25 0.21510E 02 C26 0.20800E 02 C27 0.20800E 02  
 C28 0.20800E 02 C3 0.97000E 01 C4 0.34300E 01 C5 0.34300E 01  
 C6 0.42090E-01 G53 0.20100E 00 G62 0.15926E 01

\* \* \* \*  
 TIME 4.10000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.05560E-04 DTMPCC( 15) 1.44043E-02 ARLXGCL 14) 2.19727E-03

1 THRU 5 9.333740E 00 8.695801E 00 1.005396E 01 8.245361E 00 8.600586E 00

## TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

6 THRU	10	5.629150E 01	4.138428E 00	4.169189E 00	5.561279E 00	6.099121E 00
11 THRU	15	6.730273E 00	6.950928E 00	5.631689E 01	7.050293E 00	7.049805E 00
16 THRU	20	6.912842E 00	8.198730E 00	1.764404E 00	3.170898E 00	1.800024E 01
21 THRU	25	8.042969E 00	6.747559E 00	4.923828E 00	6.234863E 00	4.810303E 00
26 THRU	30	6.730225E 00	6.350830E 00	4.793213E 00	9.660645E-01	2.560547E 00
31 THRU	31	0.0				

QRRR 0.39001E 01 QRTD 0.37517E 03 QCRA 0.21856E 02 QCTD 0.19466E 04

C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.54292E 00

C24 0.13010E 02 C25 0.98301E 00 C26 0.20800E 02 C27 0.20800E 02

C28 0.95056E 00 C3 0.97000E 01 C4 0.34300E 01 C5 0.34300E 01

C6 0.42090E-01 G53 0.20100E 00 G62 0.17350E 01

\* \* \* \*  
TIME 5.00000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.05164E-04 DTMPCC( 27) 1.14502E-01 ARLXCC( 14) 1.29395E-02

1 THRU	5	7.435303E 00	6.833984E 00	8.012207E 00	6.601074E 00	6.753906E 00
6 THRU	10	5.628345E 01	3.895752E 00	3.878652E 00	5.158691E 00	5.896973E 00
11 THRU	15	6.593994E 00	6.745361E 00	5.730859E 01	6.852783E 00	6.851074E 00
16 THRU	20	6.483643E 00	7.981445E 00	1.642578E 00	3.083740E 00	1.799756E 01
21 THRU	25	7.830811E 00	6.537842E 00	4.660400E 00	4.952637E 00	4.317627E 00
26 THRU	30	6.515381E 00	5.512939E 00	4.506592E 00	9.343262E-01	2.492920E 00
31 THRU	31	0.0				

QRRR 0.36321E 01 QRTD 0.37896E 03 QCRA 0.20620E 02 QCTD 0.19679E 04

C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.54292E 00

C24 0.59456E 00 C25 0.98301E 00 C26 0.20800E 02 C27 0.95056E 00

C28 0.95056E 00 C3 0.97000E 01 C4 0.34300E 01 C5 0.34300E 01

C6 0.42090E-01 G53 0.20100E 00 G62 0.17350E 01

\* \* \* \*  
TIME 5.10000E 01 DTIMEU 5.00002E-02 CSGMIN( 14) 6.05117E-04 DTMPCC( 28) 1.75781E-02 ARLXCC( 20) 1.46484E-03

1 THRU	5	7.201416E 00	6.615723E 00	7.791016E 00	6.414551E 00	6.514404E 00
6 THRU	10	5.626597E 01	3.334229E 00	3.553223E 00	4.857422E 00	5.670898E 00
11 THRU	15	6.406982E 00	6.505615E 00	5.629126E 01	6.632568E 00	6.636230E 00
16 THRU	20	6.157715E 00	7.760742E 00	1.543701E 00	2.996826E 00	1.799170E 01
21 THRU	25	7.611328E 00	6.299561E 00	4.348877E 00	4.510010E 00	3.935059E 00
26 THRU	30	6.213623E 00	4.729248E 00	3.849854E 00	8.986816E-01	2.422607E 00
31 THRU	31	0.0				

QRRR 0.33211E 01 QRTD 0.38240E 03 QCRA 0.19195E 02 QCTD 0.19877E 04

C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.54292E 00

REPRODUCIBILITY OF THE  
ORIGINAL PAGE IS POOR

HAMILTON STANDARD

REPORT NO.

WARMUP MODEL

## WARM UP CASE

QHX = 1500 BTU/HR

BCD 3THERMAL LPCS  
 BCD 9 TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK  
 BCD 9 WARM-UP CASE FUSIBLE HEAT SINK  
 END  
 BCD 3NODE DATA  
 CGS 1,50.,A1,5.94 \$ LIQUID AROUND PUMP  
 CGS 2,50.,A1,13.96 \$ LIQUID AROUND PUMP  
 CGS 3,50.,A1,9.7 \$ LIQUID BELOW BATTERY  
 CGS 4,50.,A1,3.43 \$ LIQUID AROUND BLADDER  
 CGS 5,50.,A1,3.43 \$ LIQUID AROUND BLADDER  
 6,50.,.168 \$ INSULATION AROUND SIDE OF MOTOR SECTION  
 7,50.,.0212 \$ METAL S/S BOTTOM BELOW MOTOR  
 8,50.,.171 \$ METAL S/S SIDE MOTOR SECTION  
 9,50.,.036 \$ METAL S/S TOP MOTOR SECTION  
 10,50.,.059 \$ METAL S/S TOP BATTERY SECTION  
 11,50.,.067 \$ METAL S/S OUTER SIDE BATTERY SECTION  
 12,50.,.067 \$ METAL S/S INNER SIDE BATTERY SECTION  
 13,50.,.0159 \$ INSULATION AT BOTTOM OF MOTOR SECTION  
 14,50.,.0666 \$ METAL S/S AROUND BATTERY  
 15,50.,.528 \$ BATTERY  
 16,50.,.159 \$ PUMP/MOTOR  
 17,50.,.0127 \$ METAL S/S BOTTOM OF BATTERY  
 18,50.,.0159 \$ INSULATION ATOP MOTOR SECTION  
 19,50.,.0601 \$ INSULATION SIDE OF BATTERY SECTION  
 20,50.,.0322 \$ FLUID IN PUMP 1 IN3  
 21,50.,.0127 \$ METAL BOTTOM OF BATTERY SECTION  
 CGS 22,50.,A1,14.99 \$ LIQUID AROUND PUMP  
 CGS 23,50.,A1,11.88 \$ LIQUID AROUND PUMP  
 CGS 24,50.,A1,13.01 \$ LIQUID AROUND PUMP  
 CGS 25,50.,A1,21.51 \$ LIQUID AROUND PUMP  
 CGS 26,50.,A1,20.8 \$ LIQUID BELOW PUMP  
 CGS 27,50.,A1,20.8 \$ LIQUID BELOW PUMP  
 CGS 28,50.,A1,20.8 \$ LIQUID BELOW PUMP  
 29,50.,.0114 \$ INSULATION ATOP BATTERY SECTION  
 30,50.,.0114 \$ INSULATION ON BOTTOM OF BATTERY SECTION  
 31,50.,.161 \$ FLUID IN OUTSIDE CIRC LOOP 5 IN3  
 -100,70.,.1 \$ ENVIRONMENT  
 END

## RELATIVE NODE NUMBERS

## ACTUAL NODE NUMBERS

1 THRU 10	1	2	3	4	5	6	7	8	9	10
11 THRU 20	11	12	13	14	15	16	17	18	19	20
21 THRU 30	21	22	23	24	25	26	27	28	29	30
31 THRU 32	31	100								

## BCD 3CONDUCTOR DATA

REM NOTE CGS CONDUCTOR CONSTANT VALUES FOR K=.375BTU-F/HR-FT2-F

REM K=1.3 BTU-F/HR-FT2-F AT 6.2F

REM K=.375 BTU-F/HR-FT2-F AT 18.8F

CGS 10,3,12,A8,.184

CGS 11,3,17,A8,.604

CGS 13,3,11,A8,.184

CGS 14,3,21,A8,.604

CGS 15,4,11,A8,26.2

CGS 16,4,5,A8,9.5E-3

CGS 17,4,14,A8,.0931

CGS 18,5,12,A8,26.2

CGS 19,5,14,A8,.0931



22,7,21,.022  
23,7,8,.0456  
24,8,9,.0552  
26,9,18,.0697  
27,9,16,2.35E-3  
28,9,10,.0363  
29,10,11,.0285  
30,10,14,.0533  
31,10,12,.0285  
32,11,19,.467  
33,11,12,.994  
35,11,21,.0155  
39,14,17,.0533  
40,14,15,109.1  
41,21,12,.0155

\$ CONDUCTANCE THRU PTFCE PLASTIC

REM CONDUCTANCES FOR CONVECTION AT 1G

42,100,13,.145  
43,100,30,.0872  
44,100,6,1.174  
45,100,19,.515  
46,100,29,.0872  
47,100,18,.145

\$ NATL CONV TO INS

\$ NATL CONV TO INS

REM END CONDUCTANCES FOR 1G EXTERNAL CONVECTION

CGS 49,1,2,A8,.035  
CGS 50,1,24,A8,.014  
CGS 51,1,25,A8,.014  
CGS 52,1,9,A8,.0151  
CGS 53,1,8,A8,1.467  
CGS 54,1,26,A8,.0122  
CGS 55,1,16,A9,.0899  
CGS 56,2,22,A8,.11  
CGS 57,2,16,A10,.0539  
CGS 58,2,12,A8,.428  
CGS 59,2,26,A8,.0288  
CGS 60,2,9,A8,.0355  
CGS 61,2,8,A8,.24  
CGS 62,22,23,A8,.5  
CGS 63,22,24,A8,.064  
CGS 64,22,26,A8,.0309  
CGS 65,22,12,A8,.425  
CGS 66,22,16,A11,.095  
CGS 67,22,9,A8,.0382  
CGS 68,23,12,A8,.1066  
CGS 69,23,26,A8,.0245  
CGS 70,23,25,A8,.067  
CGS 71,23,8,A8,1.6  
CGS 72,23,9,A8,.0302  
CGS 73,24,16,A12,.1163  
CGS 74,24,25,A8,.6  
CGS 75,24,9,A8,.0331  
CGS 76,24,26,A8,.0268  
CGS 77,25,8,A8,1.67  
CGS 78,25,25,A8,.0443  
CGS 79,25,9,A8,.0547  
CGS 80,26,27,A9,.466  
CGS 81,26,16,A8,.0548  
CGS 82,26,12,A8,.0325  
CGS 83,26,8,A8,.37  
CGS 84,27,28,A8,.466  
CGS 85,27,8,A8,.37  
CGS 86,27,12,A8,.0325

\$ CONDUCTANCE FLUID AROUND PUMP TO PUMP

\$ CONDUCTANCE FLUID AROUND PUMP TO PUMP

\$ CONDUCTANCE FLUID AROUND PUMP TO PUMP

\$ CONDUCTANCE FLUID AROUND PUMP TO PUMP

CGS 87,28,7,A8,.93Z  
 CGS 88,28,8,A8,.37  
 CGS 89,28,12,A8,.0325  
 90,18,29,7.41F-4  
 91,29,10,.01645  
 92,19,29,8.75E-4  
 93,30,21,.0419  
 94,30,19,8.75E-4

REM ONE WAY CONDUCTORS

110,-20,31,-31,3,-3,28,-28,27,-27,26,192.  
 111,-26,2,-2,1,-1,25,-25,23,-23,22,-22,24,-24,20,192.  
 116,16,20,3.27 \$ CONDUCTANCE PUMP TO PUMPED FLUID  
 117,6,13,1.59E-3 \$ CONDUCTANCE IN INSULATION  
 118,6,18,1.59E-3 \$ CONDUCTANCE IN INSULATION  
 119,6,19,1.92E-3 \$ CONDUCTANCE IN INSULATION  
 120,13,30,7.41E-4 \$ CONDUCTANCE IN INSULATION  
 121,6,8,.563 \$ INS TO CAN  
 122,7,13,.0696 \$ INS TO CAN

REM RADIATION CONDUCTORS

-100,4,14,2.05E-10  
 -101,5,14,2.05E-10  
 -102,100,13,.124E-10 \$ INSULATION E=.05  
 -103,100,30,.0747E-10 \$ INSULATION E=.05  
 -104,100,6,1.0E-10 \$ INSULATION E=.05  
 -105,100,19,.441E-10 \$ INSULATION E=.05  
 -106,100,29,.0747E-10 \$ INSULATION E=.05  
 -107,100,18,.124E-10 \$ INSULATION E=.05

END

RELATIVE CONDUCTOR NUMBERS

1 THRU	10	10	11	13	14	15	16	17	18	19	22
11 THRU	20	23	24	26	27	28	29	30	31	32	33
21 THRU	30	35	39	40	41	42	43	44	45	46	47
31 THRU	40	49	50	51	52	53	54	55	56	57	58
41 THRU	50	59	60	61	62	63	64	65	66	67	68
51 THRU	60	69	70	71	72	73	74	75	76	77	78
61 THRU	70	79	80	81	82	83	84	85	86	87	88
71 THRU	80	89	90	91	92	93	94	110	111	116	117
81 THRU	90	118	119	120	121	122	100	101	102	103	104
91 THRU	93	105	106	107							

BCD 3CONSTANTS DATA

TIMEND,3.,OUTPUT,.25

DTIMEI,.01

NLNOP,3000

DRLXCA,.05,APLXCA,.05

END

BCD 3ARRAY DATA

1,-50,.0457,6.19,.0457,6.20,1.0,18.79,1.0,18.8,.0457

100,.0457,END

-4,C1,C2,C22,C23,END

-5,C24,C25,C26,C27,END

-6,C28,C3,C4,C5,END

-7,C6,G53,G62,END

REM NOTE CHANGE IN ARRAY DATA 8 THRU 12

8,-50,.3.47,6.20,3.47,18.80,1.0,100.,1.0,END

9,-50.,1.36,6.20,1.36,18.80,1.0,100.,1.0,END

10,-50.,2.03,6.20,2.03,18.80,1.0,100.,1.0,END

11,-50.,1.78,6.20,1.78,18.80,1.0,100.,1.0,END

12,-50.,1.60,6.20,1.60,18.80,1.0,100.,1.0,END

END

FLOW CONDUCTORS, 192. BTU/HR-<sup>2</sup>F

REPRODUCIBILITY OF THE  
 ORIGINAL PAGE IS POOR

RCD 3EXECUTION  
 DIMENSION X(200)  
 NDIM=200  
 NTH=0  
 REM SET T(I) TO 6.2F  
 DO 10 I=1,31  
 T(I)=T(I)-43.8  
 10 CONTINUE

CSGDMP  
 CNFWBK

END

BCD 3VARIABLES 1

VARCSM(T	1,C	1,A1,5.94)
VARCSM(T	2,C	2,A1,13.96)
VARCSM(T	3,C	3,A1,9.7)
VARCSM(T	4,C	4,A1,3.43)
VARCSM(T	5,C	5,A1,3.43)
VARCSM(T	22,C	22,A1,14.99)
VARCSM(T	23,C	23,A1,11.88)
VARCSM(T	24,C	24,A1,13.01)
VARCSM(T	25,C	25,A1,21.51)
VARCSM(T	26,C	26,A1,20.8)
VARCSM(T	27,C	27,A1,20.8)
VARCSM(T	28,C	28,A1,20.8)
VARGSM(G	10,T	3,T 12,A8,.184)
VARGSM(G	11,T	3,T 17,A8,.604)
VARGSM(G	13,T	3,T 11,A8,.184)
VARGSM(G	14,T	3,T 21,A8,.604)
VARGSM(G	15,T	4,T 11,A8,26.2)
VARGSM(G	16,T	4,T 5,A8,9.5E-3)
VARGSM(G	17,T	4,T 14,A8,.0931)
VARGSM(G	18,T	5,T 12,A8,26.2)
VARGSM(G	19,T	5,T 14,A8,.0931)
VARGSM(G	49,T	1,T 2,A8,.035)
VARGSM(G	50,T	1,T 24,A8,.014)
VARGSM(G	51,T	1,T 25,A8,.014)
VARGSM(G	52,T	1,T 9,A8,.0151)
VARGSM(G	53,T	1,T 8,A8,1.467)
VARGSM(G	54,T	1,T 26,A8,.0122)
VARGSM(G	55,T	1,T 16,A9,.0899)
VARGSM(G	56,T	2,T 22,A8,.11)
VARGSM(G	57,T	2,T 16,A10,.0539)
VARGSM(G	58,T	2,T 12,A8,.428)
VARGSM(G	59,T	2,T 26,A8,.0288)
VARGSM(G	60,T	2,T 9,A8,.0355)
VARGSM(G	61,T	2,T 8,A8,.24)
VARGSM(G	52,T	22,T 23,A8,.5)
VARGSM(G	63,T	22,T 24,A8,.064)
VARGSM(G	64,T	22,T 26,A8,.0309)
VARGSM(G	65,T	22,T 12,A8,.425)
VARGSM(G	66,T	22,T 16,A11,.095)
VARGSM(G	57,T	22,T 9,A8,.0382)
VARGSM(G	68,T	23,T 12,A8,.1066)
VARGSM(G	69,T	23,T 26,A8,.0245)
VARGSM(G	70,T	23,T 25,A8,.067)
VARGSM(G	71,T	23,T 8,A8,1.6)
VARGSM(G	72,T	23,T 9,A8,.0302)
VARGSM(G	73,T	24,T 16,A12,.1163)
VARGSM(G	74,T	24,T 25,A8,.6)
VARGSM(G	75,T	24,T 9,A8,.0331)
VARGSM(G	76,T	24,T 26,A8,.0268)

F  
F  
F

F  
F  
F

FORTRAN STATEMENTS TO SET INITIAL TEMPERATURE  
 TO 6.2°F

VARGSM(G	77,T	25,T	8,A8,1.67)
VARGSM(G	78,T	25,T	26,A8,.0443)
VARGSM(G	79,T	25,T	9,A8,.0547)
VARGSM(G	80,T	26,T	27,A8,.466)
VARGSM(G	81,T	26,T	16,A8,.0548)
VARGSM(G	82,T	26,T	12,A8,.0325)
VARGSM(G	83,T	26,T	8,A8,.37)
VARGSM(G	84,T	27,T	28,A8,.466)
VARGSM(G	85,T	27,T	8,A8,.37)
VARGSM(G	86,T	27,T	12,A8,.0325)
VARGSM(G	87,T	28,T	7,A8,.932)
VARGSM(G	88,T	28,T	8,A8,.37)
VARGSM(G	89,T	28,T	12,A8,.0325)

ENDV1

STFSEP(92.1,Q16)

\$ MOTOR Q

STFSEP(1500.,Q31)

\$ HEAT EXCHANGER Q

END

BCD 3VARIABLES 2

END

BCD 3OUTPUT CALLS

PRNT4P

PRINTL(A4,C1,C2,C22,C23)

PRINTL(A5,C24,C25,C26,C27)

PRINTL(A6,C28,C3,C4,C5)

PRINTL(A7,C6,G53,G62)

END

POWER DISSIPATION FROM PUMP/MOTOR POWER DISSIPATION FROM HX TO FLUID IN EXTERNAL LOOP.

## TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

## WARM-UP CASE FUSIBLE HEAT SINK

* * * *	DTIMEU 0.0	CSGMIN( 01 0.0	DTMPC( 01 0.0	ARLXCC1 01 0.0
TIME 0.0				
1 THRU 5	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
6 THRU 10	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
11 THRU 15	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
16 THRU 20	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
21 THRU 25	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
26 THRU 30	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
31 THRU 32	6.200012E 00	7.000000E 01		

C1	0.59400E 01 C2	0.13960E 02 C22	0.14990E 02 C23	0.11880E 02
----	----------------	-----------------	-----------------	-------------

C24	0.13010E 02 C25	0.21510E 02 C26	0.20800E 02 C27	0.20800E 02
-----	-----------------	-----------------	-----------------	-------------

C28	0.20800E 02 C3	0.97000E 01 C4	0.34300E 01 C5	0.34300E 01
-----	----------------	----------------	----------------	-------------

C6	0.16800E 00 G53	0.50905E 01 G62	0.17350E 01
----	-----------------	-----------------	-------------

A 31 NODE PROBLEM USING LPCS

NODE 20 HAS THE CSGMIN OF 1.64900E-04, NODE 10 HAS THE CSGMAX OF 3.61852E-01

NODE C-VALUE CSG-VALUE COND TYPE G-VALUE TO NODE TYPE

1.5.940E 00 3.007E-02

31	LIN 1.214E-01	2 DIFF
32	LIN 4.858E-02	24 DIFF
33	LIN 4.858E-02	25 DIFF
34	LIN 5.240E-02	9 DIFF
35	LIN 5.090E 00	8 DIFF
36	LIN 4.233E-02	26 DIFF
37	LIN 1.223E-01	16 DIFF
78	LIN 1.920E 02	2 DIFF, ONE WAY CONDUCTOR

2 1.396E 01 7.153E-02

31	LIN 1.214E-01	1 DIFF
38	LIN 3.817E-01	22 DIFF
39	LIN 1.094E-01	16 DIFF
40	LIN 1.485E 00	12 DIFF
41	LIN 9.994E-02	26 DIFF
42	LIN 1.232E-01	9 DIFF
43	LIN 8.328E-01	8 DIFF
78	LIN 1.920E 02	26 DIFF, ONE WAY CONDUCTOR

3 9.700E 00 4.912E-02

1	LIN 6.385E-01	12 DIFF
2	LIN 2.096E 00	17 DIFF
3	LIN 6.385E-01	11 DIFF
4	LIN 2.096E 00	21 DIFF
77	LIN 1.920E 02	31 DIFF, ONE WAY CONDUCTOR

4 3.430E 00 3.755E-02

5	LIN 9.091E 01	11 DIFF
6	LIN 3.296E-02	5 DIFF
7	LIN 3.231E-01	14 DIFF
86	RAD 2.050E-10	14 DIFF

5 3.430E 00 3.755E-02

6	LIN 3.296E-02	4 DIFF
8	LIN 9.091E 01	12 DIFF
9	LIN 3.231E-01	14 DIFF

B-31

## TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

## WARM-UP CASE FUSIBLE HEAT SINK

87 RAD 2.050E-10 14 DIFF

6 1.680E-01 9.376E-02

27 LIN 1.174E 00 32 BOUN

80 LIN 1.590E-03 13 DIFF

81 LIN 1.590E-03 18 DIFF

82 LIN 1.920E-03 19 DIFF

84 LIN 5.630E-01 8 DIFF

90 RAD 1.000E-10 32 BOUN

7 2.120E-02 6.288E-03

10 LIN 2.200E-02 21 DIFF

11 LIN 4.560E-02 8 DIFF

69 LIN 3.234E 00 28 DIFF

85 LIN 6.960E-02 13 DIFF

8 1.710E-01 7.849E-03

11 LIN 4.560E-02 7 DIFF

12 LIN 5.520E-02 9 DIFF

35 LIN 5.090E 00 1 DIFF

43 LIN 8.328E-01 2 DIFF

53 LIN 5.552E 00 23 DIFF

59 LIN 5.795E 00 25 DIFF

65 LIN 1.284E 00 26 DIFF

67 LIN 1.284E 00 27 DIFF

70 LIN 1.284E 00 28 DIFF

84 LIN 5.630E-01 6 DIFF

9 3.600E-02 4.086E-02

12 LIN 5.520E-02 8 DIFF

13 LIN 6.970E-02 18 DIFF

14 LIN 2.350E-03 16 DIFF

15 LIN 3.630E-02 10 DIFF

34 LIN 5.240E-02 1 DIFF

42 LIN 1.232E-01 2 DIFF

49 LIN 1.326E-01 22 DIFF

54 LIN 1.048E-01 23 DIFF

57 LIN 1.149E-01 24 DIFF

61 LIN 1.898E-01 25 DIFF

10 5.900E-02 3.619E-01

15 LIN 3.630E-02 9 DIFF

16 LIN 2.850E-02 11 DIFF

17 LIN 5.330E-02 14 DIFF

18 LIN 2.850E-02 12 DIFF

73 LIN 1.645E-02 29 DIFF

11 6.700E-02 7.200E-04

3 LIN 6.385E-01 3 DIFF

5 LIN 9.091E 01 4 DIFF

16 LIN 2.850E-02 10 DIFF

19 LIN 4.670E-01 19 DIFF

20 LIN 9.940E-01 12 DIFF

21 LIN 1.550E-02 21 DIFF

12 6.700E-02 6.960E-04

1 LIN 6.385E-01 3 DIFF

## TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

## WARM-UP CASE FUSIBLE HEAT SINK

8 LIN 9.091E-01 5 DIFF  
18 LIN 2.850E-02 10 DIFF  
20 LIN 9.940E-01 11 DIFF  
24 LIN 1.550E-02 21 DIFF  
40 LIN 1.485E-00 2 DIFF  
47 LIN 1.475E-00 22 DIFF  
50 LIN 3.699E-01 23 DIFF  
64 LIN 1.128E-01 25 DIFF  
68 LIN 1.128E-01 27 DIFF  
71 LIN 1.128E-01 28 DIFF

13 1.590E-02 7.127E-02

25 LIN 1.450E-01 32 BOUN  
80 LIN 1.590E-03 6 DIFF  
83 LIN 7.410E-04 30 DIFF  
95 LIN 6.960E-02 7 DIFF  
88 RAD 1.240E-11 32 BOUN

14 6.660E-02 6.054E-04

7 LIN 3.231E-01 4 DIFF  
9 LIN 3.231E-01 5 DIFF  
17 LIN 5.330E-02 10 DIFF  
22 LIN 5.330E-02 17 DIFF  
23 LIN 1.091E-02 15 DIFF  
86 RAD 2.050E-10 4 DIFF  
87 RAD 2.050E-10 5 DIFF

15 5.280E-01 4.840E-03

16 1.590E-01 3.927E-02

23 LIN 1.091E-02 14 DIFF  
14 LIN 2.350E-03 9 DIFF  
37 LIN 1.223E-01 1 DIFF  
39 LIN 1.094E-01 2 DIFF  
48 LIN 1.691E-01 22 DIFF  
55 LIN 1.861E-01 24 DIFF  
63 LIN 1.902E-01 26 DIFF  
79 LIN 3.270E-00 20 DIFF

17 1.270E-02 5.909E-03

2 LIN 2.096E-00 3 DIFF  
22 LIN 5.330E-02 14 DIFF

18 1.590E-02 7.124E-02

13 LIN 6.970E-02 9 DIFF  
30 LIN 1.450E-01 32 BOUN  
72 LIN 7.410E-04 29 DIFF  
81 LIN 1.590E-03 6 DIFF  
93 RAD 1.240E-11 32 BOUN

19 6.010E-02 5.965E-02

19 LIN 4.670E-01 11 DIFF  
28 LIN 5.150E-01 32 BOUN  
74 LIN 8.750E-04 29 DIFF  
76 LIN 8.750E-04 30 DIFF  
82 LIN 1.920E-03 6 DIFF

TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

WARM-UP CASE FUSIBLE HEAT SINK

91 RAD 4.410E-11 32 BOUN

20 3.220E-02 1.649E-04  
 78 LIN 1.920E 02 24 DIFF, ONE WAY CONDUCTOR  
 79 LIN 3.270E 00 16 DIFF

21 1.270E-02 5.797E-03  
 4 LIN 2.096E 00 3 DIFF  
 10 LIN 2.200E-02 7 DIFF  
 21 LIN 1.550E-02 11 DIFF  
 24 LIN 1.550E-02 12 DIFF  
 75 LIN 4.190E-02 30 DIFF

22 1.499E 01 7.639E-02  
 38 LIN 3.817E-01 2 DIFF  
 44 LIN 1.735E 00 23 DIFF  
 45 LIN 2.221E-01 24 DIFF  
 46 LIN 1.072E-01 26 DIFF  
 47 LIN 1.475E 00 12 DIFF  
 48 LIN 1.691E-01 16 DIFF  
 49 LIN 1.326E-01 9 DIFF  
 78 LIN 1.920E 02 23 DIFF, ONE WAY CONDUCTOR

23 1.188E 01 5.938E-02  
 44 LIN 1.735E 00 22 DIFF  
 50 LIN 3.699E-01 12 DIFF  
 51 LIN 8.501E-02 26 DIFF  
 52 LIN 2.325E-01 25 DIFF  
 53 LIN 5.552E 00 8 DIFF  
 54 LIN 1.048E-01 9 DIFF  
 78 LIN 1.920E 02 25 DIFF, ONE WAY CONDUCTOR

24 1.301E 01 6.680E-02  
 32 LIN 4.858E-02 1 DIFF  
 45 LIN 2.221E-01 22 DIFF  
 55 LIN 1.861E-01 16 DIFF  
 56 LIN 2.082E 00 25 DIFF  
 57 LIN 1.149E-01 9 DIFF  
 58 LIN 9.300E-02 26 DIFF  
 78 LIN 1.920E 02 22 DIFF, ONE WAY CONDUCTOR

25 2.151E 01 1.073E-01  
 33 LIN 4.858E-02 1 DIFF  
 52 LIN 2.325E-01 23 DIFF  
 56 LIN 2.082E 00 24 DIFF  
 59 LIN 5.795E 00 8 DIFF  
 60 LIN 1.537E-01 26 DIFF  
 61 LIN 1.898E-01 9 DIFF  
 78 LIN 1.920E 02 1 DIFF, ONE WAY CONDUCTOR

26 2.080E 01 1.062E-01  
 36 LIN 4.233E-02 1 DIFF  
 41 LIN 9.994E-02 2 DIFF  
 46 LIN 1.072E-01 22 DIFF  
 51 LIN 8.501E-02 23 DIFF  
 58 LIN 9.300E-02 24 DIFF

B-34



TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK

WARM-UP CASE FUSIBLE HEAT SINK

60 LIN 1.537E-01 25 DIFF  
62 LIN 1.617E 00 27 DIFF  
63 LIN 1.902E-01 16 DIFF  
64 LIN 1.128E-01 12 DIFF  
65 LIN 1.284E 00 8 DIFF  
77 LIN 1.920E 02 27 DIFF, ONE WAY CONDUCTOR

27 2.080E 01 1.058E-01

62 LIN 1.617E 00 26 DIFF  
66 LIN 1.617E 00 28 DIFF  
67 LIN 1.284E 00 8 DIFF  
68 LIN 1.128E-01 12 DIFF  
77 LIN 1.920E 02 28 DIFF, ONE WAY CONDUCTOR

28 2.080E 01 1.049E-01

66 LIN 1.617E 00 27 DIFF  
69 LIN 3.234E 00 7 DIFF  
70 LIN 1.284E 00 8 DIFF  
71 LIN 1.128E-01 12 DIFF  
77 LIN 1.920E 02 3 DIFF, ONE WAY CONDUCTOR

29 1.140E-02 1.046E-01

20 LIN 8.720E-02 32 BOUN  
72 LIN 7.410E-04 18 DIFF  
73 LIN 1.645E-02 10 DIFF  
74 LIN 8.750E-04 19 DIFF  
92 RAD 7.470E-12 32 BOUN

30 1.140E-02 8.481E-02

26 LIN 8.720E-02 32 BOUN  
75 LIN 4.190E-02 21 DIFF  
76 LIN 8.750E-04 19 DIFF  
83 LIN 7.410E-04 13 DIFF  
89 RAD 7.470E-12 32 BOUN

31 1.610E-01 8.385E-04

77 LIN 1.920E 02 20 DIFF, ONE WAY CONDUCTOR

\* \* \* \*  
TIME 0.0 DTIMEU 0.0 CSGMIN( 0) 0.0 DTMPCC( 0) 0.0 ARLXCC( 0) 0.0

1 THRU 5	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
6 THRU 10	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
11 THRU 15	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
16 THRU 20	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
21 THRU 25	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
26 THRU 30	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00	6.200012E 00
31 THRU 32	6.200012E 00	7.000000E 01				

C1	0.59400E 01 C2	0.13960E 02 C22	0.14990E 02 C23	0.11880E 02
C24	0.13010E 02 C25	0.21510E 02 C26	0.20800E 02 C27	0.20800E 02
C28	0.20800E 02 C3	0.97000E 01 C4	0.34300E 01 C5	0.34300E 01
C6	0.16800E 00 G53	0.50905E 01 G62	0.17350E 01	

\* \* \* \*  
TIME 2.50000E-01 DTIMEU 5.00011E-03 CSGMIN( 20) 1.64899E-04 DTMPCC( 29) 2.50732E-01 ARLXCC( 7) 9.76563E-04

1 THRU

5

7.135742E 00

7.461426E 00

1.435132E 01

7.221436E 00

6.493896E 00

TRANSIENT WATER/KHFZ/ETHANOL FUSIBLE HEAT SINK

WARM-UP CASE FUSIBLE HEAT SINK

6 THRU 10  
11 THRU 15  
16 THRU 20  
21 THRU 25  
26 THRU 30  
31 THRU 32

4.737402E 01  
7.427490E 00  
3.155493F 01  
1.538477E 01  
8.500732E 00  
1.448169E 01

1.386499E 01  
6.568359E 00  
1.397974E 01  
6.295654E 00  
1.053735E 01  
7.000000E 01

8.430176E 00  
5.043311E 01  
4.957910E 01  
6.413818E 00  
1.284277E 01

1.025220E 01  
6.399414E 00  
4.031274E 01  
6.247314E 00  
5.526538E 01

8.336426E 00  
6.393555E 00  
5.670410E 00  
6.571289E 00  
5.000537E 01

C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.11880E 02  
C24 0.13010E 02 C25 0.21510E 02 C26 0.20800E 02 C27 0.20800E 02  
C28 0.20800E 02 C3 0.97000E 01 C4 0.34300E 01 C5 0.34300E 01  
C6 0.16800E 00 G53 0.46502E 01 G62 0.17210E 01

\* \* \* \*  
TIME 5.00000E-01 DTIMEU 5.00011E-03 CSGMINI 20) 1.64899E-04 DTMPCCI 25) 7.29983E-02 ARLXCC( 7) 1.22070E-03

1 THRU 5  
6 THRU 10  
11 THRU 15  
16 THRU 20  
21 THRU 25  
26 THRU 30  
31 THRU 32

1.103760E 01  
5.105908E 01  
8.635010E 00  
3.256641E 01  
1.632300E 01  
1.252539E 01  
1.547119E 01

1.148169E 01  
1.597534E 01  
7.328613E 00  
1.465576E 01  
7.787598E 00  
1.375464E 01  
7.000000E 01

1.511035E 01  
1.162573E 01  
5.281885E 01  
5.179102E 01  
8.637451E 00  
1.455444E 01

8.424072E 00  
1.304248E 01  
6.847168E 00  
4.141040E 01  
7.243896E 00  
6.015845E 01

7.181641E 00  
1.080029E 01  
6.836182E 00  
7.666260E 00  
9.426025E 00  
5.279199E 01

C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.11880E 02  
C24 0.13010E 02 C25 0.21510E 02 C26 0.20800E 02 C27 0.20800E 02  
C28 0.20800E 02 C3 0.97000E 01 C4 0.34300E 01 C5 0.34300E 01  
C6 0.16800E 00 G53 0.36356E 01 G62 0.15438E 01

\* \* \* \*  
TIME 7.50000E-01 DTIMEU 5.00011E-03 CSGMINI 20) 1.64898E-04 DTMPCCI 21) 7.29980E-02 ARLXCC( 14) 1.46484E-03

1 THRU 5  
6 THRU 10  
11 THRU 15  
16 THRU 20  
21 THRU 25  
26 THRU 30  
31 THRU 32

1.380005E 01  
5.230518E 01  
9.794434E 00  
3.520923E 01  
1.908936E 01  
1.468262E 01  
1.834302E 01

1.404663E 01  
1.821899E 01  
8.443359E 00  
1.686963E 01  
1.096802E 01  
1.555298E 01  
7.000000E 01

1.767212E 01  
1.489722E 01  
5.348804E 01  
5.293726E 01  
1.196069E 01  
1.651147E 01

9.568848E 00  
1.670972E 01  
7.491455E 00  
4.196387E 01  
1.012427E 01  
6.090186E 01

8.237305E 00  
1.277979E 01  
7.476318E 00  
1.054224E 01  
1.264990E 01  
5.358691E 01

C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.11880E 02  
C24 0.13010E 02 C25 0.21510E 02 C26 0.20800E 02 C27 0.20800E 02  
C28 0.20800E 02 C3 0.97000E 01 C4 0.34300E 01 C5 0.34300E 01  
C6 0.16799E 00 G53 0.27614E 01 G62 0.12250E 01

\* \* \* \*

TIME 1.00000E 00 DTIMEU 5.00011E-03 CSGMIN( 20) 1.64897E-04 DTMPC( 27) 5.18799E-01 ARLXCC( 26) 7.56836E-03

1 THRU 5	1.602417E 01	1.635156E 01	2.116870E 01	1.070190E 01	9.463867E 00
6 THRU 10	5.325073E 01	2.293481E 01	1.785547E 01	2.030908E 01	1.452808E 01
11 THRU 15	1.094556E 01	9.704834E 00	5.472412E 01	8.313232E 00	8.294922E 00
16 THRU 20	3.813721E 01	1.993555E 01	5.407324E 01	4.250220E 01	1.342236E 01
21 THRU 25	2.257174E 01	1.367432E 01	1.443823E 01	1.300366E 01	1.498584E 01
26 THRU 30	1.738501E 01	2.081738E 01	2.111401E 01	6.122681E 01	5.468652E 01
31 THRU 32	2.122656E 01	7.000000E 01			

C1 0.59400E 01 C2 0.13960E 02 C22 0.14990E 02 C23 0.11880E 02

C24 0.13010E 02 C25 0.21510E 02 C26 0.20800E 02 C27 0.95056E 00

C28 0.95056E 00 C3 0.44329E 00 C4 0.34300E 01 C5 0.34300E 01

C6 0.16799E 00 G53 0.20213E 01 G62 0.96961E 00

\* \* \* \*  
TIME 1.25000E 00 DTIMEU 5.00011E-03 CSGMIN( 20) 1.64897E-04 DTMPC( 22) 7.90771E-01 ARLXCC( 21) 4.71191E-02

1 THRU 5	2.416357E 01	2.417188E 01	2.507251E 01	1.181250E 01	1.081128E 01
----------	--------------	--------------	--------------	--------------	--------------

TRANSIENT WATER/KHF2/ETHANOL FUSIBLE HEAT SINK WARM-UP CASE FUSIBLE HEAT SINK

6 THRU	10	5.508130F 01	2.619385E 01	2.591064F 01	2.576392E 01	1.625586E 01
11 THRU	15	1.207422E 01	1.112207E 01	5.585083E 01	9.266113E 00	9.246094E 00
16 THRU	20	4.149561E 01	2.302515F 01	5.553296E 01	4.303027E 01	1.758252E 01
21 THRU	25	2.562866E 01	2.362622E 01	2.390299F 01	1.719141E 01	2.399365E 01
26 THRU	30	2.432666E 01	2.452271F 01	2.476363E 01	6.150171E 01	5.555005E 01
31 THRU	32	2.531055E 01	7.000000E 01			

C1 0.27146E 00 C2 0.63797E 00 C22 0.68504E 00 C23 0.54292E 00

C24 0.13010E 02 C25 0.98301E 00 C26 0.95056E 00 C27 0.95056E 00

C28 0.95056E 00 C3 0.44329E 00 C4 0.34300E 01 C5 0.34300E 01

C6 0.16799E 00 G53 0.14470F 01 G62 0.50000E 00

\* \* \*  
TIME 1.50000E 00 DTIMFU 5.00011E-03 CSGMIN( 20) 1.64896E-04 DTMPCC( 20) 1.09204E 00 ARLXCC( 2) 4.54102E-02

1 THRU 5 7.169604E 01 7.199585E 01 7.584497E 01 1.329297E 01 1.380981E 01

6 THRU 10 6.36187E 01 6.996973E 01 6.579199E 01 4.961108E 01 1.918896E 01

11 THRU 15 1.380322E 01 1.520410E 01 6.584961E 01 1.080591E 01 1.076465E 01

16 THRU 20 8.537085E 01 6.702539E 01 6.095313E 01 4.375244E 01 5.886011E 01

21 THRU 25 6.898071E 01 6.916748E 01 6.998853E 01 6.856567E 01 7.062769E 01

26 THRU 30 7.279370E 01 7.379761F 01 7.480981E 01 6.187207E 01 6.492627E 01

31 THRU 32 7.644653E 01 7.000000E 01

C1 0.27146E 00 C2 0.63797E 00 C22 0.68504E 00 C23 0.54292E 00

C24 0.59456E 00 C25 0.98301E 00 C26 0.95056E 00 C27 0.95056E 00

C28 0.95056E 00 C3 0.44329E 00 C4 0.34300E 01 C5 0.34300E 01

C6 0.16799E 00 G53 0.14670E 01 G62 0.50000E 00

\* \* \*  
TIME 1.75000E 00 DTIMFU 5.00011E-03 CSGMIN( 20) 1.64896E-04 DTMPCC( 5) 1.79028E 00 ARLXCC( 2) 4.56543E-02

1 THRU 5 1.198315E 02 1.201404E 02 1.239287E 02 1.580322E 01 3.565161E 01

6 THRU 10 7.762378E 01 1.158750E 02 1.111938F 02 8.542407E 01 2.565308E 01

11 THRU 15 1.718994E 01 3.790527E 01 8.028345E 01 1.365674E 01 1.357080E 01

16 THRU 20 1.339448E 02 1.116008E 02 7.162622E 01 4.506274E 01 1.169668E 02

21 THRU 25 1.134092E 02 1.172817E 02 1.181296E 02 1.167056E 02 1.187822E 02

26 THRU 30 1.239724E 02 1.219404E 02 1.229180E 02 5.258994E 01 7.869409E 01

31 THRU 32 1.246128E 02 7.000000E 01

C1 0.27146E 00 C2 0.63797E 00 C22 0.68504E 00 C23 0.54292E 00

C24 0.59456E 00 C25 0.98301E 00 C26 0.95056E 00 C27 0.95056E 00

C28 0.95056E 00 C3 0.44329E 00 C4 0.34300E 01 C5 0.15675E 00

C6 0.16799E 00 G53 0.14670E 01 G62 0.50000E 00

\* \* \*